Task Order 9.B

Energy Savings Performance Contracting for UH-Hilo

Approved by: The fell Marun Date: nas 116, 2011

TASK ORDER 9.B FOR PROVIDING TECHNICAL ASSISTANCE FOR ENERGY EFFICIENCY AND RENEWABLE ENERGY ENERGY SAVINGS PERFORMANCE CONTRACTING UH-HILO

CONTRACTOR'S NAME AND ADDRESS: InSynergy Engineering, Inc. 828 Fort Street Mall, Suite 500 Honolulu, Hawaii 96813

CONTRACT NO. 59499 TASK ORDER NO.: 9.B. PERIOD OF PERFORMANCE OF TASK ORDER: through April 30, 2012 BUDGET AMOUNT FOR TASK ORDER: \$6,600.00 DATE PROPOSED: November 11, 2011

PROJECT TITLE: TECHNICAL ASSISTANCE FOR ENERGY PERFORMANCE CONTRACTING FOR UH-HILO

1. CONTRACT TASK WORK STATEMENT

Provide technical assistance for energy efficiency and renewable energy, with an emphasis on Energy Savings Performance Contracting.

2. EXPECTED OUTCOMES

PROJECT GOAL: Assist State and County agencies, universities and colleges with Energy Savings Performance Contracting

PROJECT OBJECTIVES, INCLUDING METRICS

Provide services as directed and prioritized by STATE to implement Energy Savings Performance Contracting in selected entities; including reporting metrics on projected jobs created and energy savings achieved

3. PLANNED ACTIVITIES -- WORKPLAN

Provide services to include, but not be limited to:

- a) Ongoing assistance and support services including, but not limited to: updating and reviewing ESPC program procedures and documentation, such as draft solicitations; providing review and analysis for energy assessments and audits; participating in annual reconciliation reviews; providing educational/technical training services as requested; preparing policy/issue papers; and, providing detailed technical input on specific issues.
- b) Provide technical assistance to the University of Hawaii at Hilo for their Performance Contract Project, as follows:
 - i. Phase 1 Analysis & Report Pre-Final Review and Comment.

- Phase 1 Analysis & Report Final Review/Edit and Back-Check¹, for technical adequacy, clarity of analysis and report, including proposed actions.
- iii. EPC RFP Draft Solicitation Review and Comment.
- iv. EPC RFP Draft Solicitation Back-Check Review.
- v. Provide responses to miscellaneous questions and opinions from UH-Hilo.
- vi. Written copies of reviews, analyses, questions, and summaries of discussions with UH-Hilo.

Technical questions on this amendment may be directed to Ted LeJeune, Project Manager, University of Hawaii at Hilo, Facilities Planning & Construction, telephone: 808.974.7595; email: thl@hawaii.edu.

c) Provide other services as directed by STATE.

4. **REPORTING**

CONTRACTOR/SUBCONTRACTOR will keep STATE informed by email of any activities under this project and will copy DBEDT Project Manager email: eraman@dbedt.hawaii.gov by email).

CONTRACTOR will submit quarterly narrative reports no later than 3 calendar days following the end of the quarter to STATE in a format approved by STATE.

5. PROCESS FOR IMPLEMENTATION.

STATE will notify CONTRACTOR, or CONTRACTOR will notify STATE, of need for technical assistance by email. CONTRACTOR will obtain approval to proceed from STATE. (This shall be accomplished by email.)

6. SCHEDULE OF PERFORMANCE

a) Quarterly reports beginning the Quarter ending December 31, 2011 through April 31, 2012.

Quarterly Reporting Schedule

Date Due	Report
2012	
January 3	Narrative Progress and Jobs Report (Oct-Dec 2011)
April 3	Narrative Progress and Jobs Report (Jan-Mar 2012)
April 30	Narrative Progress and Jobs Report (April 2012)

b) Deliverable dates for additional reports, analyses, and other items under Tasks 3.a and 3.b will be determined based on approvals from STATE.

7. DELIVERABLES

- a) Quarterly reports from Quarter ending December 31, 2011 to April 30, 2012.
- b) Deliverables, and schedules will be determined for Tasks 3.a. and 3.b.

¹ Quality control loop function prior to release of final report

8. **BUDGET DOLLARS AND DETAILS BY TASK** Attached is a budget by dollars and task.

INSYNERGY TASK ORDER NO. 9.B _ TA for UH-Hilo 11/16/2011 9:02 AM

BUDGET BY DOLLARS AND TASKS

Task Order 9.B				
Contract No.: 59499				
	Qty	Unit	Rate	TOTAL COST
CONTRACTOR - InSynergy Engineeringing				
Review/Report/Invoice Processing - Engineer	2	Hour	\$113.70	\$227.40
Review/Report/Invoice Processing - Admin	4	Hour	\$54.90	\$219.60
Subtotal				\$447.00
State Excise Tax			0.04712	\$21.06
TOTAL, CONTRACTOR, NTE \$500.00				\$468.06
SUBCONTRACTOR - Synchronous Energy Systems, Inc.				
Technical Assistance - University of Hawali, Hilo				
Phase 1 - Analysis & Report Pre-Final Review and				
Comment	8	Hour	\$125.00	\$1,000.00
Phase 1 - Analysis & Report Final Review and Comment	4	Hour	\$125.00	\$500.00
EPC RFP Draft Solicitation Review and Comment	16	Hour	\$125.00	\$2,000.00
EPC RFP Draft Solicitation Back Check Review	8	Hour	\$125.00	\$1.000.00
Availability for Mis. Questions and Opinions	8	Hour	\$125.00	\$1,000.00
Subtotal				\$5,500.00
State Excise Tax			0.04712	\$259.16
Subtotal				\$5,759.16
Reimburseable Expenses				
Round Trip Airfare	1	Trip	250	\$250.00
Car Rental	1	Trip	50	\$50.00
Subtotal				\$300.00
TOTAL, SUBCONTRACTOR, NTE \$6,100.00				\$6,059.16
	TOTAL	TASK O	RDER NTE	\$6,600.00

Task Order 9.C

Review of Life of Contract Plan Template

Approved: aller Date: 8/16/12 Date:

81.5

Amendment 1 TASK ORDER 9.C

FOR PROVIDING TECHNICAL ASSISTANCE FOR REVIEW OF LIFE OF CONTRACT PLAN TEMPLATE

CONTRACTOR'S NAME AND ADDRESS:

InSynergy Engineering, Inc.

828 Fort Street Mall, Suite 500 Honolulu, Hawaii 96813

CONTRACT NO. 59499

TASK ORDER NO.: 9.C

PERIOD OF PERFORMANCE OF TASK ORDER: through April 30, 2012 BUDGET AMOUNT FOR TASK ORDER: <u>Not to exceed \$5,500.00 (</u>\$2,855.92 +\$2,617.80) DATE PROPOSED: <u>August 14, 2011</u>

PROJECT TITLE: TECHNICAL ASSISTANCE FOR REVIEW OF LIFE OF CONTRACT PLAN TEMPLATE

1. CONTRACT TASK WORK STATEMENT Provide technical assistance for review of the draft Life of Contract Plan template <u>and develop a matrix/checklist of essential documents.</u>

2. EXPECTED OUTCOMES

PROJECT GOAL: Provide this Life of Contract Plan template <u>and</u> <u>Matrix/checklist</u> for use in the State of Hawaii and post on the DBEDT website for accessibility.

PROJECT OBJECTIVES, INCLUDING METRICS

Provide services as directed and prioritized by STATE to implement Energy Savings Performance Contracting in selected entities; including reporting metrics on projected jobs created and energy savings achieved

3. PLANNED ACTIVITIES --WORKPLAN

Provide services to include, but not be limited to:

- a) Review the draft of the template for the Life of Contract Plan and provide suggested changes and comments, using track changes as appropriate.
- b) <u>Develop a checklist/matrix of essential ESPC documents with some</u> discussion of the purpose for maintaining this records system.

4. **REPORTING**

CONTRACTOR/SUBCONTRACTOR will keep STATE informed by email of any activities under this project and will copy DBEDT Project Manager email: <u>eraman@dbedt.hawaii.gov</u> by email).

InSynergy Task Order 9.C. Amendment 1, 8-14-2012

CONTRACTOR will submit quarterly narrative reports no later than 3 calendar days following the end of the quarter to STATE in a format approved by STATE.

5. PROCESS FOR IMPLEMENTATION.

STATE will notify CONTRACTOR of need for technical assistance by email. CONTRACTOR will obtain approval to proceed from STATE. (This shall be accomplished by email.)

6. SCHEDULE OF PERFORMANCE

a) Quarterly reports beginning the Quarter ending December 31, 2011 through November 30, 2012.

Quartenly	Schedule
Date Due	Report
2012	1
January 3, 2012	Narrative Progress and Jobs Report (Oct-Dec 2011)
April 3, 2012	Narrative Progress and Jobs Report (Jan-Mar 2012)
Nov 30 2012	Narrative Progress Report (Aug 10-Nov 30, 2012)

c) LOC plan review is due no later than December 21, 2011.

d) Checklist/matrix is due no later than November 30, 2012.

7. DELIVERABLES

- a) Quarterly reports from start of Task Order to November 30, 2012.
- b) LOC Plan review

c) Checklist/matrix for ESPC documents

THE FOLLOWING INFORMATION SHOULD BE PROVIDED ON THE ATTACHED SPREADSHEET. The Timesheet format is to be used for reporting quarterly jobs for CONTRACTOR/SUBCONTRACTOR.

8. BUDGET DOLLARS AND DETAILS BY TASK

Attached is a budget by dollars and task.

InSynergy Task Order 9.C. Amendment 1, 8-14-2012

2lle 8/16/12

34

7.4

BUDGET BY DOLLARS AND TASKS

Task Order 9.C				
Contract No.: 59499				
a .	Qty	Unit	Rate	TOTAL COST
CONTRACTOR - InSynergy Engineeringing				
Review/Report/Invoice	2	Hour	\$113.70	\$227.40
Processing				
Subtotal				\$227.40
State Excise Tax			0.04712	\$10.72
TOTAL NTE \$250.00				\$238.12
SUBCONTRACTOR - Synchronous Energy Syste	n ms, Inc.			
Technical Assistance to review the draft Life of	F			£
Contract Plan. Suggest changes and provide				
comments.	20	Hour	\$125.00	\$2,500.00
Subtotal				\$2,500.00
State Excise Tax			0.04712	\$117.80
Subtotal				\$2,617.80
TOTAL NTE \$2,700.00				\$2,617.80
AMENDMENT 1	×. B			7
Develop a checklist/matrix of essential				. I. (
ESPC documents	20	Hour	\$125.00	\$2,500.00
Subtotal				\$2,500.00
State Excise Tax			0.04712	\$117.80
Subtotal		g et i		\$2,617.80
TOTAL NTE \$2,700.00				<u>\$2,617.8</u>
	TOTA	L TASK (DRDER NTE	\$5,500.0

Task Order 9.E

Energy Savings Performance Contracting to the Board of Water Supply (BWS)

Approved by: Manan Date: 9/17/2012

TASK ORDER 9.E

PROVIDE TECHNICAL ASSISTANCE FOR ENERGY SAVINGS PERFORMANCE CONTRACTING TO THE BOARD OF WATER SUPPLY (BWS)

CONTRACTOR'S NAME AND ADDRESS: InSynergy Engineering, Inc. 828 Fort Street Mall, Suite 500 Honolulu, Hawaii 96813

CONTRACT NO. 59499 TASK ORDER NO.: 9.E. PERIOD OF PERFORMANCE OF TASK ORDER: through December 15, 2012 BUDGET AMOUNT FOR TASK ORDER: \$2,220.00 DATE PROPOSED: September 17, 2012

PROJECT TITLE: TECHNICAL ASSISTANCE FOR ENERGY PERFORMANCE CONTRACTING FOR BOARD OF WATER SUPPLY (BWS), Honolulu

1. CONTRACT TASK WORK STATEMENT

Provide technical assistance for energy efficiency and renewable energy, with an emphasis on Energy Savings Performance Contracting.

2. EXPECTED OUTCOMES

PROJECT GOAL: Assist State and County agencies, universities and colleges with Energy Savings Performance Contracting

PROJECT OBJECTIVES, INCLUDING METRICS

Provide services as directed and prioritized by STATE to implement Energy Savings Performance Contracting in selected entities; including reporting metrics on projected jobs created and energy savings achieved

3. PLANNED ACTIVITIES -- WORKPLAN

Perform all professional services as directed and prioritized by the Board of Water Supply to implement Energy Savings Performance Contracting for selected BWS facilities. Services will include, but not be limited, to ongoing assistance and support services such as updating and reviewing ESPC program procedures and documentation; draft solicitations; providing review and analysis for energy assessments and audits; participating in annual reconciliation reviews; providing educational/technical training services as requested; preparing policy/issue papers; and, providing detailed technical input on specific issues.

(a) Assist BWS with the development of an Invitation for Proposals (IFP) solicitation package, including, but not limited, to reviewing and revising drafts of IFP and TFP and participating in conference calls.

INSYNERGY TASK ORDER NO. 9.E TA for BWS 9/18/2012 8:17 AM

b) Provide other services as directed by STATE.

4. **REPORTING**

CONTRACTOR/SUBCONTRACTOR will keep STATE informed by email of any activities under this project and will copy DBEDT Project Manager email: eraman@dbedt.hawaii.gov by email).

Technical questions on this task order may be directed to Project Manager Marc S. O. Chun, P.E., Civil Engineer, Water Resources Division, Board of Water Supply, telephone: 808.748.5906; email: mchun@hbws.org

5. PROCESS FOR IMPLEMENTATION.

STATE will notify CONTRACTOR, or CONTRACTOR will notify STATE, of need for technical assistance by email. CONTRACTOR will obtain approval to proceed from STATE. (This shall be accomplished by email.)

6. SCHEDULE OF PERFORMANCE

a) Quarterly reports beginning the Quarter ending September 30, 2012 through December 15, 2012.

Quarterly Reporting Schedule

Date Due	Report
2012	
December	Narrative Progress and Jobs Report for period ending Dec 20, 2012

7. DELIVERABLES

a) Quarterly report

b) Deliverables will be determined for Task 3.a.

8. **BUDGET DOLLARS AND DETAILS BY TASK** Attached is a budget by dollars and task.

INSYNERGY TASK ORDER NO. 9.E _ TA for BWS 9/18/2012 8:17 AM

BUDGET BY DOLLARS AND TASKS

Task Order 9.E				
Contract No.: 59499		1	u	
	Qty	Unit	Rate	TOTAL COST
CONTRACTOR - InSynergy Engineeringing				
Review/Report/Invoice	1	Hour	\$113.70	\$113.70
Processing				
Subtotal				\$113.70
State Excise Tax			0.04712	\$5.36
TOTAL NTE \$120.00				\$119.06
SUBCONTRACTOR - Synchronous Energy Syst	ems, Inc.	经撤回		
Technical Assistance to the Board of Water				15 (1)
Supply to implement Energy Savings				
Performance Contracting	16	Hour	\$125.00	\$2,000.00
Subtotal				\$2,000.00
State Excise Tax			0.04712	\$94.24
Subtotal				\$2,094.24
TOTAL NTE \$2,100.00				\$2,094.24
	TOTAI	TASK C	DRDER NTE	\$2,220.00
				.46
				22.2

Task Order 9.F

Develop Frequently Asked Questions (FAQS) List

Approved by: 5/12 Date: 9/18/12

TASK ORDER 9.F

TECHNICAL ASSISTANCE FOR ENERGY PERFORMANCE CONTRACTING TO DEVELOP FREQENTLY ASKED QUESTIONS (FAQS) LIST

CONTRACTOR'S NAME AND ADDRESS:

InSynergy Engineering, Inc. 828 Fort Street Mall, Suite 500 Honolulu, Hawaii 96813

CONTRACT NO. 59499 TASK ORDER NO.: 9.F. PERIOD OF PERFORMANCE OF TASK ORDER: through December 15, 2012 BUDGET AMOUNT FOR TASK ORDER: \$5,500.00 DATE PROPOSED: September 18, 2012

PROJECT TITLE: DEVELOP FREQENTLY ASKED QUESTIONS (FAQS) LIST

1. CONTRACT TASK WORK STATEMENT

Provide technical assistance for energy efficiency and renewable energy, with an emphasis on Energy Savings Performance Contracting.

2. EXPECTED OUTCOMES

PROJECT GOAL: Assist State and County agencies, universities and colleges with Energy Savings Performance Contracting

PROJECT OBJECTIVES, INCLUDING METRICS

Provide services as directed and prioritized by STATE to implement Energy Savings Performance Contracting in selected entities; including reporting metrics on projected jobs created and energy savings achieved

3. PLANNED ACTIVITIES -- WORKPLAN

Perform all professional services as directed and prioritized by State to include, but not be limited, to ongoing assistance and support services such as updating and reviewing ESPC program procedures and documentation; preparation of FAQs, draft solicitations; providing review and analysis for energy assessments and audits; participating in annual reconciliation reviews; providing educational/technical training services as requested; preparing policy/issue papers; and, providing detailed technical input on specific issues.

(a) Using materials previously developed, such as Brief FAQs, and additional questions derived from activities related to current State and county energy performance contracts, develop a list of frequently asked questions for a basic understanding of ESPC organized by categories and subheadings (including financing) for STATE use.

(b) Provide draft to STATE for review and approval;

(c) Provide final version of FAQs to STATE for review and approval; and

(d) Provide other services as directed by STATE.

4. **REPORTING**

CONTRACTOR/SUBCONTRACTOR will keep STATE informed by email of any activities under this project and will copy DBEDT Project Manager email: eraman@dbedt.hawaii.gov by email).

5. PROCESS FOR IMPLEMENTATION.

STATE will notify CONTRACTOR, or CONTRACTOR will notify STATE, of need for technical assistance by email. CONTRACTOR will obtain approval to proceed from STATE. (This shall be accomplished by email.)

6. SCHEDULE OF PERFORMANCE

a) Quarterly reports beginning the Quarter ending September 30, 2012 through December 15, 2012.

Quarterly Reporting Schedule

Date Due	Report
2012	
December	Narrative Progress and Jobs Report for period ending Dec 20, 2012

7. DELIVERABLES

- a) Quarterly report
- b) Draft FAQs on or before November 15, 2012
- b) Final FAQS list on or before December 15, 2012

8. BUDGET DOLLARS AND DETAILS BY TASK

Attached is a budget by dollars and task.

BUDGET BY DOLLARS AND TASKS

Task Order 9.F				
Contract No.: 59499				
	Qty	Unit	Rate	TOTAL COST
CONTRACTOR - InSynergy Engineeringing				
Review/Report/Invoice	2	Hour	\$113.70	\$227.40
Processing				
Subtotal				\$227.40
State Excise Tax			0.04712	\$10.72
TOTAL NTE \$250.00				\$238.12
SUBCONTRACTOR - Synchronous Energy Syst	ems, Inc.			
Technical Assistance to develop Frequently			2	
Asked Questions (FAQS) list.	40	Hour	\$125.00	\$5,000.00
Subtotal				\$5,000.00
State Excise Tax			0.04712	\$235.60
Subtotal	1			\$5,235.60
TOTAL NTE \$5,250.00		2		\$5,235.60
	TOTAL	TASK C	DRDER NTE	\$5,500.00

Task Order 12

Final Narrative Progress Report

Approved by: " Date:

TASK ORDER 12 FOR PROVIDING A FINAL NARRATIVE PROGRESS REPORT

CONTRACTOR'S NAME AND ADDRESS:

InSynergy Engineering, Inc. 828 Fort Street Mall, Suite 500 Honolulu, Hawaii 96813 CONTRACT NO. 59499 TASK ORDER NO.: 12 PERIOD OF PERFORMANCE OF TASK ORDER: through November 30, 2012 BUDGET AMOUNT FOR TASK ORDER: <u>\$5,800.00</u> DATE PROPOSED: June 26, 2012

PROJECT TITLE: FINAL NARRATIVE PROGRESS REPORT FOR CONTRACT NO. 59499

1. TASK WORK STATEMENT

Provide a final narrative progress report to assess the status of the work accomplished for Contract No. 59499.

2. EXPECTED OUTCOMES

PROJECT GOAL: Final narrative progress report.

PROJECT OBJECTIVES, INCLUDING METRICS

Provide narrative discussion of project goals and objectives, significant results, best practices, major findings or conclusions, key outcomes, major deliverables, reports, and other achievements.

3. PLANNED ACTIVITIES - WORKPLAN

Provide a concise narrative assessment of the status of work and include the following information:

Description	Page Limit
a) Title Page (see sample)	(Pages not counted)
b) Acknowledgment and Disclaimer(On inside of Title Page	
c) Table of Contents including list of tables, list of appendices, list of figures, as appropriate	

.1

INSYNERGY TASK ORDER NO.12 06/29/2012

d) Comparision of the actual accomplishments by Task with the goals and objectives established for the period of the Contract and reasons why the established goals were not met, as appropriate.	A.,
 e) A <u>discussion</u> of what was accomplished during the Contract period by Task, including project goals and objectives, significant results, best practices, major findings or conclusions (lessons learned), key outcomes, major deliverables, reports, and/ or other achievements. This section should not contain any proprietary data or other information not subject to public release. If such information is important, do not include the information, but include a note in the report advising the reader to contact the Principal Investigator or the Project Director for further information. (USDOE does not recommend aggregating quarterly reports for this section) 	(8-10 pages)
 f) Cost Status. Show approved budget by task, budget period, and actual costs incurred; show leverage separately 	2
 g) As applicable, a description of any product produced or technology transfer activities accomplished during this reporting period, such as: Publications (list journal name, volume, issue); conference papers; or other public releases of results. Attach or send copies of public releases to the report; Web site or other internet sites that reflect the results of this project; Networks or collaborations fostered; Technologies/Techniques; Inventions/Patent Applications; and Other products, such as data or databases, physical collections, audio or video, software or netware, models, educational aid or curricula, instruments or equipment 	(this item is additional to the suggested 10-12 page limit)
equipment.	Total Page Limit – 25 Pages

INSYNERGY TASK ORDER NO.12 06/29/2012 2

4. **REPORTING**

CONTRACTOR/SUBCONTRACTOR will keep STATE informed by email of any activities under this project and will copy DBEDT Project Manager email: <u>eraman@dbedt.hawaii.gov</u> by email).

Technical questions on the Task Order may be directed to Elizabeth Raman, PhD, SID-DBEDT, telephone: 808.587-3806.

CONTRACTOR will submit quarterly narrative reports no later than 3 calendar days following the end of the quarter to STATE in a format approved by STATE.

5. SCHEDULE OF PERFORMANCE

a) Quarterly reports beginning the Quarter ending September 30, 2012, through December 20, 2012.

Quarterly Reporting Schedule

Date Due	Report
2012	
October 3	Narrative Progress and Jobs Report (Jul - Sep 2012)
December 20	Narrative Progress and Jobs Report (Oct – Dec 20, 2012)

Schedule for Task

Date Due	Activity	
2012		2
March – August	Outline for Final Report	
November 30	Draft Final Narrative Progress Report	
December 14	Final Narrative Progress Report	2

6. **DELIVERABLES**

- a) Quarterly reports from start of Task Order to December 20, 2012.
- b) Written reports for:
 - (1) Outline for Final Report
 - (2) Draft Final Narrative Progress Report
 - (3) Final Narrative Progress Report

INSYNERGY TASK ORDER NO.12 06/29/2012

BUDGET – attached as separate spreadsheet Estimated engineering hours by Task (does include other types of hours or expenses)

8.

INSYNERGY TASK ORDER NO.12 06/29/2012

Task Order 12					
Contract No : 59/99					
	Qty	n.	Unit	Rate	TOTAL COST
CONTRACTOR - InSynergy					
Engineeringing					Entra House Sta
OUTLINE FOR FINAL REPORT,			100		
INCLUDING METRICS		1	Hour	¢1E2 00	¢152.00
Proj Mgr Mech Engr		T	Hour	\$155.90	\$155.90 \$454.90
Mechanical Engineer		4	Hour	\$115.70	\$454.00 ¢E4.00
Admin Support	1	Т	Hour	\$54.90	\$54.90
Subtotal	<u>*</u>			0.04712	\$21.27
State Excise Tax		j.		0.04712	\$51.27
TOTAL NTE \$700.00		6		•	\$694.87
DRAFT FINAL NARRATIVE PROGRESS					
REPORT	5				
Proj Mgr Mech Engr		2	Hour	\$153.90	\$307.80
Mechanical Engineer		28	Hour	\$113.70	\$3,183.60
Admin Support	20	4	Hour	\$54.90	\$219.60
Subtotal					\$3,711.00
State Excise Tax				0.04712	\$174.80
TOTAL NTE \$3,900.00	×	34			\$3,885.86
FINAL NARRATIVE PROGRESS REPORT					
Proj Mgr Mech Engr		1	Hour	\$153.90	\$153.9
Mechanical Engineer		8	Hour	\$113.70	\$909.6
Admin Support		1	Hour	\$54.90	\$54.9
Subtotal			5		\$1,118.4
State Excise Tax				0.04712	\$52.7
TOTAL NTE \$1,200.00		144	×		\$1,171.1
ć		0050			1
	NTE \$5,800.00	DEK			\$5,751.8

INSYNERGY TASK ORDER NO.12 06/29/2012 5 .

APPENDIX 2.0

MAJOR DELIVERABLES

APPENDIX 2.1

Solar Water Heating Impact Assessment

STATE OF HAWAII

SOLAR WATER HEATING IMPACT ASSESSMENT

(1992 - 2011)

Prepared For: Department of Business and Economic Development and Tourism (DBEDT) State of Hawaii

FINAL

December 18, 2012

Prepared by:



828 Fort Street Mall, Suite 500 • Honolulu, Hawaii 96813

Tel: 808 521-3773

Acknowledgment

This material is based upon work supported by the U.S. Department of Energy under Award Number DE-EE0000216 through State of Hawai'i Contract Number 59499, Supplement No. 1.

Disclaimer

"This report was prepared as an account of work sponsored by an agency of the United States Government and the State of Hawai'i. Neither the United States Government nor any agency thereof, the State of Hawai'i, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately-owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government, the State of Hawai'i, or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government, the State of Hawai'i, or any agency thereof."

TABLE OF CONTENTS

1.0	EXECUTIVE SUMMARY								
2.0	SOLAR WATER HEATING IMPACT ASSESSMENT 1								
3.0	METH	/IETHODOLOGY /BASIS FOR ASSESSMENT ANALYSIS							
	3.1	Quantificatior	of Solar Water Systems Installations6						
	3.2	2 Estimate of Avoided Electrical Use Per Solar Water Heating System Installation							
	3.3	Estimate of Avoided Fossil Fuel and Carbon Dioxide Emissions							
4.0	REFE	RENCES							
LIST (Table	OF TAB 1	LE Solar	Water Heating System Impact Assessment (1992 - 2011)						
LIST (Figure	OF FIGI 9 1	JRES Numb Bor ye	er of Solar Water Heating Systems Installed Statewide						
Figure 2		Aggre	Aggregate Impact of Solar Water Heating Systems Installed Statewide on Avoided Electrical Consumption Per Year (1992-2011)						
Figure 3		Aggre Avoid	Aggregate Impact of Solar Water Heating Systems Installed Statewide Avoided Fuel Oil Use and CO2 Emissions Per year (1992-2011)						
ATTA Attach Attach	CHMEN Iment 1 Iment 2	TS Tax C PY11 26) Sc	redits Claimed (1977-2011) - Hawaii Energy Technical Reference Manual No. 2011 (Pages 18-						
Attach	nment 3	Energ	Energy Star - Save Money And More With Energy Star Qualified Solar Water Heaters						
Attach	nment 4	Sayin	g Mahalo To Solar Savings: A Billing Analysis Of Solar Water						
Attach	nment 5	EPA (Emiss Powe	EPA Combined Heat And Power Partnership, Fuel And Carbon Dioxide Emissions Savings Calculation Methodology For Combined Heat And Power Systems, August 2012						
Attach	nment 6	U.S. E F15:	U.S. Energy Information Administration, State Energy Data System, Table F15: Total Petroleum Consumption Estimate, 2010						
Attach	nment 7	Hawa	ii Energy Statistics						
Attach	nment 8	Energ House	Energy-Data-Trend, Table 5.8 Residential Energy Consumption Per Household						

STATE OF HAWAII SOLAR WATER HEATING IMPACT ASSESSMENT (1977-2011)

1.0 EXECUTIVE SUMMARY:

This report reviews the number of solar water heating systems installed throughout the State of Hawaii since the state tax credit for solar systems was first implemented in 1977, and analyzes the savings in fossil fuels and electricity realized by their installation over the past 20 years from 1992 through 2011. The primary findings of this analysis are as follows:

- The total number of solar water heating systems installed since 1977 is 103,305.
- Based on an average 20 year life expectancy, the 74,018 total aggregate systems installed from 1992 through 2011 currently saves the State 152,847 MWh in electricity per year, which is sufficient to power 21,695 homes annually.
- This avoided electricity savings corresponds to an annual savings of 221,337 barrels of fuel oil that would have otherwise been required to generate this electricity, and a resulting reduction of 116,699 tons in annual avoided CO2 emissions.
- The total estimated value of the solar water installations that were installed cumulatively over the 20 year period from 1992 through 2011 is approximately \$332 million.
- The estimated value of the State Tax Credits that were provided under the same period totaled approximately \$116 million.
- There is a direct correlation between the number of solar water heating installations installed annually and the level of support from State and Federal credits.

2.0 SOLAR WATER HEATING IMPACT ASSESSMENT

From the inception of the State Tax Credit for solar water heating systems, the total number of solar systems that have been installed in the State of Hawaii from 1977 to 2011 was 103,305. These installations include those that were replaced over the years so the actual number of solar systems in service is lower.

Since solar water heating systems have a 20 year project life, the present impact of the solar heating systems that are installed and operating is conservatively estimated based on the systems that have been installed over the past 20 years from 1992 through 2011. Based on the methodology and basis for assessment analysis presented in the subsequent sections, the annual aggregate and cumulative impact of the installation of the solar water systems over the

most current 20 year period is conservatively estimated and summarized in Table 1 below and in the Figures that follow:

	Table 1. Solar Water Heating System Impact Assessment (1992 - 2011)											
				Total	Total							
				Aggregate	Aggregate	1						1
	Number of	Aggregate	Total	Fuel Oil	Avoided	1			Ave Solar			1
	Solar	Number of	Aggregate	savings at	CO2	1			Water			1
	Water	Solar	Annual	9123	Emissions				Heating		Estimated	1
	Heating	Water	MWh	BTU/KWh	at 1527 lbs	1			System		Total Annual	1
	Systems	Heating	Savings at	heat rate	Co2/MWH	1			Installed		Solar Water	Estimated
	Installed	Systems	2065	(Barrels of	(tons of				Cost (\$		Heating	Total Annual
	Statewide	Installed	KWh/yr per	oil Per	Co2 Per	TAX CREDIT LEVEL		per		Installed Cost	State Tax	
Year	Per Year	Since 1992	System	Year)	Year)	Total	State	Federal	system)	Basis	(\$)	Credit (\$)
1992	1,261	1261	2604	3771	1988	35%	35%	0%	\$3,440	Actual Data	\$4,337,840	\$1,518,244
1993	1,500	2761	5701	8256	4353	35%	35%	0%	\$3,440	From 1992	\$5,160,000	\$1,806,000
1994	1,744	4505	9303	13471	7103	35%	35%	0%	\$3,440	From 1992	\$5,999,360	\$2,099,776
1995	1,800	6305	13020	18854	9941	35%	35%	0%	\$3,440	From 1992	\$6,192,000	\$2,167,200
1996	2,043	8348	17239	24963	13162	35%	35%	0%	\$3,440	From 1992	\$7,027,920	\$2,459,772
1997	2,750	11098	22917	33187	17497	35%	35%	0%	\$3,440	From 1992	\$9,460,000	\$3,311,000
1998	3,586	14684	30322	43910	23151	35%	35%	0%	\$3,440	From 1992	\$12,335,840	\$4,317,544
1999	3,599	18283	37754	54672	28825	35%	35%	0%	\$3,440	From 1992	\$12,380,560	\$4,333,196
2000	3,473	21756	44926	65057	34301	35%	35%	0%	\$3,440	From 1992	\$11,947,120	\$4,181,492
2001	2,846	24602	50803	73568	38788	35%	35%	0%	\$3,440	From 1992	\$9,790,240	\$3,426,584
2002	3,094	27696	57192	82820	43666	35%	35%	0%	\$3,440	From 1992	\$10,643,360	\$3,725,176
2003	3,363	31059	64137	92876	48968	35%	35%	0%	\$3,440	From 1992	\$11,568,720	\$4,049,052
2004	3,014	34073	70361	101889	53720	35%	35%	0%	\$3,440	From 1992	\$10,368,160	\$3,628,856
2005	3,531	37604	77652	112448	59288	35%	35%	0%	\$3,440	From 1992	\$12,146,640	\$4,251,324
2006	4,534	42138	87015	126006	66436	65%	35%	30%	\$5,250	Actual Data	\$23,803,500	\$8,331,225
2007	5,411	47549	98189	142187	74967	65%	35%	30%	\$5,250	Actual Data	\$28,407,750	\$9,942,713
2008	8,424	55973	115584	167377	88249	65%	35%	30%	\$5,250	Actual Data	\$44,226,000	\$15,479,100
2009	8,974	64947	134116	194212	102397	65%	35%	30%	\$5,250	Actual Data	\$47,113,500	\$16,489,725
2010	5,597	70544	145673	210949	111222	65%	35%	30%	\$6,600	Actual Data	\$36,940,200	\$12,929,070
2011	3,474	74018	152847	221337	116699	65%	35%	30%	\$6,625	Actual Data	\$23,015,250	\$8,055,338
Totals												1
Over the												1
20 Year												1
Period												1
(1992-												1
2011):												1
	74018	74018	1237356	1791810	944722						\$332,863,960	\$116,502,386

For the purpose of comparison with the latest available data on Hawaii total petroleum use and total electrical consumption in 2010, the 70,544 total solar water heating systems that were installed over the past 19 years from 1992 to 2010 saved an aggregate of 145,673 MWh per year in electricity. This amounted to an annual savings of 210,949 barrels of fuel oil that would have otherwise been required to generate this electricity, and a resulting reduction of 111,222

tons in avoided CO2 emissions. Accordingly to Table F15: Total Petroleum Consumption Estimates, 2010, (Attachment 6) and the Hawaii Energy Statistics (Attachment 7), the State of Hawaii consumed a total of 12,610,000 barrels of oil to generate 10,013,000 MWh of electricity in 2010. The 70,544 total solar water heating systems that were in use in 2010 resulted in a 1.7% reduction in total fuel oil used for electricity and a 1.5% reduction in electrical consumption Statewide. The total aggregate electrical savings in 2010 from the installation of solar water heating systems was sufficient to displace the total annual electrical use of 20,677 homes, based on the average household electrical use of 7,045 kwh per year from the State of Hawaii Energy Data and Trends March 2011 Table 5.8 (Attachment 8).

For the most recent year in 2011, the 74,018 total solar water heating systems that have been installed over the past 20 years saved an aggregate of 152,847 MWh per year in electricity. This amounted to an annual savings of 221,337 barrels of fuel oil that would have otherwise been required to generate this electricity, and a resulting reduction of 116,699 tons in avoided CO2 emissions. Using the same State of Hawaii Energy Data and Trends data, the total aggregate electrical savings in 2011 from the installation of solar water heating systems was sufficient to displace the electricity used by 21,695 homes annually.

The total estimated value of the solar water installations that were installed cumulatively over the 20 year period from 1992 through 2011 is approximately \$332 million, and the estimated value of the State Tax Credits that were provided totaled approximately \$116 million.

Figure 1 illustrates the number of solar water installations that have been installed annually from 1992 through 2011. There is a significant increase in the number of systems installed during the 2008 through 2010 timeframe which appears attributable to the reinstitution of the Federal tax credits in 2006.



The aggregate impact of the number of solar water installations that have been installed from 1992 through 2011 on avoided electrical use is shown in Figure 2. The cumulative to date savings resulting from the 74,018 total solar water heating systems installed between 1992 through 2011 totaled 1,237,356 MWh in electricity over this 20 year period.



The aggregate impact of the number of solar water installations that have been installed from 1992 through 2011 on avoided fuel oil use and CO2 emissions is shown in Figure 3. The cumulative impact of the solar water heating systems has resulted in a total savings of 1,791,810 barrels of fuel oil that would have otherwise been required to generate this electricity, and a 944,722 ton reduction in avoided CO2 emissions over the entire period from 1992-2011.



Based on this assessment, the installation of solar water heating systems in Hawaii over the past 20 years has made a significant contribution in reducing electrical energy use and the amount of fuel oil imported to the State, while also lowering the amount of CO2 and other flue stack air emissions that would have otherwise been generated.

3.0 METHODOLOGY/BASIS FOR ASSESSMENTANALYSIS:

3.1 Quantification of Solar Water Heating Systems Installations:

The number of solar water heating system installations in the State of Hawaii for the period from 1992 through 2011 of 74,018 systems installed cumulatively over this period was derived from "Solar System Tax Credits Claimed (1977-2011)" (See Attachment 1). This data was derived and compiled from the following sources which are documented on page 2 of the report: the State of Hawaii Tax Reports, the Hawaii Solar Energy Association (HSEA), the electric utility companies (HECO, HELCO, MECO, and KIUC), Hawaii Energy, DBEDT, and the Military. The

solar water installations tallied during this period reflect the number of systems that were documented to have received State and Federal tax credits and electric utility rebates. Since the life expectancy of a solar water heating system is 20 years (see Attachment 2 - Solar Water Heaters : ENERGY STAR), it is assumed all of the solar water systems installed over the past 20 years are still in service at this time. While some of these systems may have already been replaced, it is reasonable to assume that the majority of these systems have remained operational. In addition, some of the older solar water systems during the preceding period from 1977 through 1991 that total an additional 29,287 installations that are not included in this assessment also remain functional and would actually increase the impact of the solar system installed over the past 20 years if they were also counted. It is also assumed that all of these solar water heating systems were installed to displace the use of electrical water heaters since the electric utility company rebates provided a significant incentive for their installation.

3.2 Estimate of Avoided Electrical Use per Solar Water Heating System Installation:

The avoided electrical consumption per solar water heating system of 2,065 kwh per year per system is based on the analysis from Hawaii Energy - Technical Reference Manual No. 2011 Program Year 3 July 2011 to June 2012 (Excerpt pages 18-26 – Attachment 3). This analysis is based on the following which appear to be reasonable:

- 1. Average Hot Water Use Per Person: 13.3 Gallons per day
- 2. Average Occupants per Solar Water Heating System: 3.77
- 3. Final Water Heating Temperature: 130 degrees F
- 4. Initial Cold Water Supply Temperature: 75 degrees F
- 5. Electrical Resistance Heater COP: 0.90
- 6. Fraction of Water Heating Accomplished by Solar on an Annual Basis: 90%

The Hawaii Energy estimate of 2,065 kwh per year of electricity use avoided by installation of each solar water heating system is also consistent with an independent study, "Saying Mahalo to Solar Savings: A Billing Analysis of Solar Water Heaters in Hawaii," (Attachment 4) that was prepared in conjunction with the Hawaii Public Utilities Commission . This report calculated the savings of solar water heating installations in Hawaii using a statistical analysis of the utility bills before and after the solar water heating systems were installed in 6,302 homes in 2009 and 2010. According to their summary, " ... Our impact estimate of 1,912 kWh is close to the current ex ante savings value of 2,066 kWh included in the Hawaii Energy PY2010 Technical

Reference Manual (TRM). Given that the savings estimates are so close, we did not recommend any change to the TRM value currently in use by the program..."

Based on these two reports, the avoided electrical consumption per solar water heating system of 2,065 kwh per year per system appears reasonable and is the basis for the electrical savings utilized in this assessment.

3.3 Estimate of Avoided Fossil Fuel and Carbon Dioxide Emissions:

The fossil fuel consumption and carbon dioxide emissions avoided from the savings in electricity due to the installation of the solar hot water heating systems is based on the heat rate of 9,123 Btu/kwh and a CO2 Emission Factor of 1,527 lb/Mwh for the average of all electrical power generation in the Hawaiian Islands. These figures were developed in the analysis from "Fuel and Carbon Dioxide Emissions Savings Calculation Methodology for Combined Heat and Power Systems, U.S. Environmental Protection Agency, Combined Heat and Power Partnership August 2012" (Attachment 5). A conversion factor of 150,000 Btu per gallon was used to convert from energy to residual fuel oil.

4.0 REFERENCES:

- 1. Solar System Tax Credits Claimed (1977-2011), Ron Richmond (Attachment 1)
- Solar Water Heaters : ENERGY STAR, <u>http://www.energystar.gov/index.cfm?c=solar_wheat.pr_savings_benefits</u> (Attachment 2)
- Hawaii Energy Technical Reference Manual No. 2011 Program Year 3 July 2011 to June 2012 (Excerpt pages 18-26 – Attachment 3)
- Saying Mahalo to Solar Savings: A Billing Analysis of Solar Water Heaters in Hawaii, Jenny Yaillen, Evergreen Economic/Chris Ann Dickerson, CAD Consulting/Wendy Takanishi and John Cole, Hawaii Public Utilities Commission (Attachment 4)
- Fuel and Carbon Dioxide Emissions Savings Calculation Methodology for Combined Heat and Power Systems, U.S. Environmental Protection Agency, Combined Heat and Power Partnership August 2012 (Attachment 5)
- 6. Table F15: Total Petroleum Consumption Estimates, 2010, U.S. Energy Information Administration (Attachment 6)
- Hawaii Energy Statistics <u>http://energy.hawaii.gov/resources/dashboard-statistics</u> (Attachment 7)
- 8. State of Hawaii Energy Data and Trends March 2011 Table 5.8 (Attachment 8)
ATTACHMENT 1

TAX CREDITS CLAIMED (1977-2011)





-	1	1	r	1	r	1	r –	r	r –	r –	r –	-	-	-	1	r	r	r	r –	1	r –	1	-	-	r –						r –	-	<u> </u>	1	-		-
																						er											Total	New SFD	1,861	1,995	
																						hot wat	<u>.</u> .											Total	460	768	
																						ting solar	icements'										ary SFD	est City	120	215	
																						ed their exist	burnout repla	.96	eplacements.								Milit	Actus Fore	340	553	
																						iey replac	ed to as "	ents in 19	ournout re	ted.							SFD	justed	1,401	1,227	
																						or rebates if th	ms are referre	out replaceme	usted reflect I	s are oversta							Sector New	Variance Ad	458	442	
																						re eligible fo	hese syster	acking burne	ot been adj	lled system							Private	Total	1,859	1,669	
																						ers wei	ems. T	egan tra	have n	of insta								Total	5,597	3,474	
																						custor	am syst	ECO b	ed here	number							New	SFD	1,861		
																						electric	n progra	-CO, M	ints liste	, total r							stems	Kauai	80	د.	
																						dential	ems witl	SO, HEI	tem cor	ordingly							ofit Sy:	Maui	523	534	
																						1. Resi	syste	2. HEO	 Syst 	4. Acc							ed Retr	Hawaii	547	543	
																						Note:											Rebate	Oahu I	2,586	2,397	
	SOURCE	State Tax Report	HSEA	State Tax Report	HSEA	HSEA	HECO, HELCO, MECO, KIUC	HECO, HELCO, MECO, KIUC	HECO, HELCO, MECO, KIUC	HECO, HELCO, MECO, KIUC	HECO, HELCO, MECO, KIUC	HECO, HELCO, MECO, KIUC	HECO, HELCO, MECO, KIUC	HECO, HELCO, MECO, KIUC	HECO, HELCO, MECO, KIUC	HECO, HELCO, MECO, KIUC	HEP, KIUC, DBEDT, Military	HEP, KIUC, DBEDT, Military																			
AVER.	COST	\$2,135	\$2,907	\$3,031	\$3,346	\$3,500	\$3,659	\$3,601	\$3,519	\$3,897	\$2,230	\$3,213	\$3,142	\$3,016	\$3,751	n/a	\$3,440	n/a	n/a	n/a	n/a	n/a									\$5,250				\$6,600	\$6,625	
LEVEL	Fed.	%0	30%	30%	40%	40%	40%	40%	40%	40%	%0	%0	%0	%0	%0	%0	%0	%0	%0	%0	%0	%0	%0	%0	%0	%0	%0	%0	%0	%0	30%	30%	30%	30%	30%	30%	
SREDIT I	State	10%	10%	10%	10%	10%	10%	10%	10%	10%	15%	15%	15%	20%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	
TAX C	Total	10%	40%	40%	50%	50%	50%	50%	50%	50%	15%	15%	15%	20%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	35%	65%	65%	65%	65%	65%	65%	
STATEWIDE		1,101	4,016	4,375	4,704	6,445	4,407	3,148	4,464	6,740	592	354	316	327	1,180	1,314	1,261	1,500	1,744	1,800	2,043	2,750	3,586	3,599	3,473	2,846	3,094	3,363	3,014	3,531	4,534	5,411	8,424	8,974	5,597	3,474	
YEAR 3		77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	66	00	01	02	03	04	05	06	07	08	60	10	11	

SOLAR SYSTEMS INSTALLED STATEWIDE and within the TRI-SERVICE AREA

Tax Credits Claimed 1977-2011

ATTACHMENT 2

PY11 - HAWAII ENERGY TECHNICAL REFERENCE MANUAL NO. 2011 (PAGES 18-26) SECTION 8. (REEM) RESIDENTIAL ENERGY EFFICIENCY MEASURES



Program Year 3 July 2011 to June 2012

8 (REEM) Residential Energy Efficiency Measures

8.1 High Efficiency Water Heating

8.1.1 Solar Water Heater

Measure ID: See Table 7.3

Version Date & Revision History Draft date: February 24, 2010 Effective date: July 1, 2010 End date: TBD

Referenced Documents:

- Energy and Peak Demand Impact Evaluation Report of the 2005-2007 Demand Management Programs – (KEMA 2005-07)
- Econorthwest TRM Review 6/23/10
- Evergreen TRM Review 2/23/12

TRM Review Actions:

- 6/23/10 Rec. # 6 For PY 2010, adjust claimed demand savings based on participant data from all service territories covered. Adjust Demand Savings based on participant data weighted average of KEMA results across all counties. Change from 0.50 to 0.46 kW. non-military – Adopted and incorporated into PY2010-1 TRM.
- 6/23/10 Rec. # 7 For PY 2010, include a discussion of shell losses in the savings analysis and supporting documentation. Discussion included in PY2010-1 TRM.
- 10/5/11 Currently Under Review.

Major Changes:

- Eliminated Military figure as no foreseeable military retrofit applications will be received.
- Demand change to weighted average from KEMA 2008. 0.46 kW
- Changed individual water usage from 13.3035 to 13.3

Measure Description:

Replacement of Electric Resistance Water Heater with a Solar Water Heater designed for a 90% Solar Fraction. The new Solar Water Heating systems most often include an upgrade of the hot water storage tank sized at 80 or 120 gallons.

Systems must comply with Hawaii Energy Solar Standards and Specifications which call out:

- Panel Ratings
- System Sizing
- Installation orientation de-rating factors
- Hardware and mounting systems

Shell Losses:

The increase in size from a 40 or 60 gallon to an 80 or 120 gallon standard electric resistance water heater would in and of itself increase the "shell" losses of the system. These shell losses are the result of a larger surface area exposing the warm water to the cooler environment and thus more heat lost to the environment through conduction through the tank. Engineering calculations by Econorthwest puts this at a 1% increase in losses. This is further reduced by 90% as the solar water system provides that fraction of the annual water heating requirements.



Program Year 3 July 2011 to June 2012

Baseline Efficiencies:

Baseline usage is a 0.9 COP Electric Resistance Water Heater. The baseline water heater energy consumption is by a single 4.0kW electric resistance element that is controlled thermostatically on/off controller based of tank finish temperature set point. The tank standby loss differences between baseline and high efficiency case are assumed to be negligible.

Demand Baseline has been determined by field measurements by KEMA 2005-07 report. The energy baseline also comes from the KEMA 2005-07 report and is supported by engineering calculations shown in this TRM.

Building Types	Demand Baseline(kW)	Energy Baseline (kWh)
Residential	0.57	2,733

High Efficiency:

Solar Water Heater designed for a 90% Solar Fraction. The Solar Systems use solar thermal energy to heat the water 90% of the time and continue to utilize electricity to operate the circulation pump and provide heating through a 4.0 kW electric resistance element when needed.

Solar Contractors do not favor Photo-Voltaic powered DC circulation pumps as they have proven less reliable in the field than an AC powered circulation pump.

The electric resistance elements in the high efficiency case do not have load control timers on them.

The energy is the design energy of a 90% solar fraction system with circulation pump usage as metered by KEMA 2008.

The on peak demand is the metered demand found by KEMA 2008.

Building Types	Demand High Efficiency (kW)	Energy High Efficiency (kWh)	Circ. Pump %
Residential	0.07	379	28%

Energy Savings:

Solar Water Heater Gross Savings before operational adjustments:

Building Types	Demand Savings (kW)	Energy Savings (kWh)
Residential	0.46	2,354

Operational Factor	Adjustment Factor
Solar Fraction Performance (sfp)	0.94
Persistence Factor (pf)	0.93
Demand Coincidence Factor (cf)	1.0

Solar Water Heater Net Savings after operational adjustments:

Building Types	Demand Savings (kW)	Energy Savings (kWh)
Residential	0.46	2,065



Program Year 3 July 2011 to June 2012

Savings Algorithms			
Solar Water Heater - Non-Military Single Family Hom	1e		
Energy per Day (BTU) = (Gallons per Day) x (lbs. per Gal	l.) x (Temp	o Rise) x (Energy to Raise Water Temp)	
Hot Water needed per Person		13.3 Gallons per Day per Person	HE
Average Occupants	х	3.77 Persons	KEMA 2008
Household Hot Water Usage		50.141 Gallons per Day	
Mass of Water Conversion		8.34 lbs/gal	
Finish Temperature of Water	_	130 deg. F Finish Temp	
Temperature Rise		55 deg. F Temperature Rise	
Energy to Raise Water Temp		1.0 BTU / deg. F / lbs.	_
Energy per Day (BTU) Needed in Tank		23,000 BTU/Day	_
Energy per Day (BTU) Needed in Tank		23,000 BTU/Day	
BTU to kWh Energy Conversion	÷	3,412 kWh / BTU	
Energy per Day (kWh)		6.7 kWh / Day	
Days per Month	Х	30.4 Days per Month	
Energy (kWh) per Month		205 kWh / Month	
Days per Year	Х	365 Days per Year	
Energy (kWh) Needed in Tank to Heat Water per Year		2,459 kWh / Year	
Elec. Res. Water Heater Efficiency	÷	0.90 COP	
Base SERWH Energy Usage per Year at the Meter		2,732 kWh / Year	KEMA 2008 - HECO
Design Annual Solar Fraction		90% Water Heated by Solar System 10% Water Heated by Remaining Backup Element	Program Design
Energy Usage per Year at the Meter		2,732 kWh / Year	
	x	10% Water Heated by Remaining Backup Element	
Back Up Element Energy Used at Meter		273 kWh / Year	
Circulation Pump Energy		0.082 kW	KEMA 2008
Pump Hours of Operation	х	1,292 Hours per Year	KEMA 2008
Pump Energy used per Year		106 kWh / Year	
Back Up Element Energy Used at Meter		273 kWh / Year	72%
Pump Energy used per Year	+	<u>106</u> kWh / Year	28%
Design Solar System Energy Usage		379 kWh / Year	
Base SERWH Energy Usage per Year at the Meter		2,732 kWh / Year	
	-	379 kWh / Year	
Design Solar System Energy Savings		2,353 kWh / Year	
Design Solar System Energy Savings		2,353 kWh / Year	
Periormance Factor		0.94 pi	
	x	2,065 kWh / Year	KEMA 2008
Residential Solar Water Heater Energy Savings		2,065 kWh / Year Savings	
Base SERWH Element Power Consumption		4.0 kW	
Coincidence Factor	х	<u>0.143</u> cf	8.6 Minutes per hour
Base SERWH On Peak Demand		0.57 kW On Peak	KEMA 2008
Base SERWH On Peak Demand	-	0.57 kW On Peak	
Solar System Metered on Peak Demand	-	0.11 kW On Peak	KEMA 2008
-		0.46 kW On Peak	
Residential Solar Water Heater Demand Savings		0.46 kW Savings	7



Program Year 3 July 2011 to June 2012

Operating Hours See Table above.

Loadshape TBD

Freeridership/Spillover Factors TBD

Persistence

The persistence factor has been found to be 0.93 based in the KEMA 2005-07 report that found 7% of the systems not operational.

Lifetime

15 years

Measure Costs and Incentive Levels

Table 1 – SWH Measure Costs and Incentive Levels

Description	Unit	Incentive	Incremental Cost
Non-Military	\$	750	\$6,600

Component Costs and Lifetimes Used in Computing O&M Savings TBD

Reference Tables

None



Program Year 3 July 2011 to June 2012

8.1.2 Solar Water Heating Loan Interest Buydown (LIB)

Measure ID: See Table 7.3

Version Date & Revision History Draft date: May 22, 2011 Effective date: November 1, 2011 End date: TBD

Referenced Documents:

- Energy and Peak Demand Impact Evaluation Report of the 2005-2007 Demand Management Programs (KEMA 2005-07)
- Econorthwest TRM Review 6/23/10
- Evergreen TRM Review 2/23/12

TRM Review Actions:

- 6/23/10 Rec. # 6 For PY 2010, adjust claimed demand savings based on participant data from all service territories covered. Adjust Demand Savings based on participant data weighted average of KEMA results across all counties. Change from 0.50 to 0.46 kW. non-military – Adopted and incorporated into PY2010-1 TRM.
- 6/23/10 Rec. # 7 For PY 2010, include a discussion of shell losses in the savings analysis and supporting documentation. Discussion included in PY2010-1 TRM.
- 10/5/11 Currently Under Review.

Major Changes:

- Eliminated Military figure as no foreseeable military retrofit applications will be received.
- Demand change to weighted average from KEMA 2008. 0.46 kW
- Changed individual water usage from 13.3035 to 13.3

Measure Description:

The Solar Water Heating Loan Interest Buydown Program offers eligible borrowers an interest buy down of \$1,000 (with a minimum loan of \$5,000) toward the financing of a solar water heating system from a participating lender – see <u>www.hawaiienergy.com</u> for a list of participating lenders.

Replacement of Electric Resistance Water Heater with a Solar Water Heater designed for a 90% Solar Fraction. The new Solar Water Heating systems most often include an upgrade of the hot water storage tank sized at 80 or 120 gallons.

Systems must comply with Hawaii Energy Solar Standards and Specifications which call out:

- Panel Ratings
- System Sizing
- Installation orientation de-rating factors
- Hardware and mounting systems

Shell Losses:

The increase in size from a 40 or 60 gallon to an 80 or 120 gallon standard electric resistance water heater would in and of itself increase the "shell" losses of the system. These shell losses are the result of a larger surface area exposing the warm water to the cooler environment and thus more heat lost to the environment through conduction through the tank. Engineering calculations by Econorthwest puts this at a 1% increase in losses. This is further reduced by 90% as the solar water system provides that fraction of the annual water heating requirements.

Baseline Efficiencies:

Baseline usage is a 0.9 COP Electric Resistance Water Heater. The baseline water heater energy consumption is by a single 4.0 kW electric resistance element that is controlled thermostatically on/off



Program Year 3 July 2011 to June 2012

controller based of tank finish temperature set point. The tank standby loss differences between baseline and high efficiency case are assumed to be negligible.

Demand Baseline has been determined by field measurements by KEMA 2005-07 report. The energy baseline also comes from the KEMA 2005-07 report and is supported by engineering calculations shown in this TRM.

Building Types	Demand Baseline(kW)	Energy Baseline (kWh)
Residential	0.57	2,733

High Efficiency:

Solar Water Heater designed for a 90% Solar Fraction. The Solar Systems use solar thermal energy to heat the water 90% of the time and continue to utilize electricity to operate the circulation pump and provide heating through a 4.0 kW electric resistance element when needed.

Solar Contractors do not favor Photo-Voltaic powered DC circulation pumps as they have proven less reliable in the field than an AC powered circulation pump.

The electric resistance elements in the high efficiency case do not have load control timers on them.

The energy is the design energy of a 90% solar fraction system with circulation pump usage as metered by KEMA 2008.

The on peak demand is the metered demand found by KEMA 2008.

Building Types	Demand High Efficiency (kW)	Energy High Efficiency (kWh)	Circ. Pump %
Residential	0.07	379	28%

Energy Savings:

Solar Water Heater Gross Savings before operational adjustments:

	Building Types	Demand Savings (kW)	Energy Savings (kWh)
F	Residential	0.46	2,354

Operational Factor	Adjustment Factor
Solar Fraction Performance (sfp)	0.94
Persistence Factor (pf)	0.93
Demand Coincidence Factor (cf)	1.0

Solar Water Heater Net Savings after operational adjustments:

Building Types	Demand Savings (kW)	Energy Savings (kWh)
Residential	0.46	2,065



Program Year 3 July 2011 to June 2012

Savings Algorithms Solar Water Heater - Non-Military Single Family Hom	e		
, ·, ·, ·, ·, ·			
Energy per Day (BTU) = (Gallons per Day) x (lbs. per Gal	.) x (Tem	p Rise) x (Energy to Raise Water Temp)	
Hot Water needed per Person		13.3 Gallons per Day per Person	HE
Average Occupants	х	3.77 Persons	KEMA 2008
Household Hot Water Usage		50.141 Gallons per Day	
Mass of Water Conversion		8.34 lbs/gal	
Finish Temperature of Water		130 deg. F Finish Temp	
Initial Temperature of Water	-	75 deg. F Initial Temp	
Temperature Rise		55 deg. F Temperature Rise	
Energy to Raise Water Temp		1.0 BTU / deg. F / lbs.	_
Energy per Day (BTU) Needed in Tank		23,000 BTU/Day	
Energy per Day (BTU) Needed in Tank		23,000 BTU/Day	
BTU to kWh Energy Conversion	÷	3,412 kWh / BTU	
Energy per Day (kWh)		6.7 kWh / Day	
Days per Month	x	30.4 Days per Month	
Energy (kWh) per Month		205 kWh / Month	
Days per Year	х	365 Days per Year	
Energy (kWh) Needed in Tank to Heat Water per Year		2,459 kWh / Year	
Elec. Res. Water Heater Efficiency	÷	0.90 COP	
Base SERWH Energy Usage per Year at the Meter		2,732 kWh / Year	KEMA 2008 - HECO
Design Annual Solar Fraction		90% Water Heated by Solar System 10% Water Heated by Remaining Backup Element	Program Design
Energy Usage per Year at the Meter		2,732 kWh/Year	
	x	10% Water Heated by Remaining Backup Element	
= Back Up Element Energy Used at Meter		273 kWh / Year	
Circulation Pump Energy		0.082 kW	KEMA 2008
Pump Hours of Operation	x	1.292 Hours per Year	KEMA 2008
Pump Energy used per Year		106 kWh / Year	
Back Up Element Energy Used at Meter		273 kWh / Year	72%
Pump Energy used per Year	+	106 kWh / Year	28%
 Design Solar System Energy Usage		379 kWh / Year	2070
Base SERWH Energy Usage per Year at the Meter		2 732 kWh / Year	
Design Solar System Energy Usage	-	379 kWh / Year	
Design Solar System Energy Sage		2.252 kWh / Yoar	
Bosign Golal Gystem Energy Savings		2,553 KWN/ Tear	
Design Solar System Energy Savings		2,353 kWh / Year	
Performance Factor		0.94 pf	HE
Persistance Factor	x	0.93 pf	KEMA 2008
-		2,065 kWh / Year	KEMA 2008
Residential Solar Water Heater Energy Savings		2,065 kWb / Year Savings	

Operating Hours

See Table above.

Loadshape TBD

Freeridership/Spillover Factors TBD



Program Year 3 July 2011 to June 2012

Persistence

The persistence factor has been found to be 0.93 based in the KEMA 2005-07 report that found 7% of the systems not operational.

Lifetime

15 years

Measure Costs and Incentive Levels

Hawaii Energy will be allowed to claim credit for the fraction of the energy and demand savings and total resource benefits that is proportional to the share of customer incentive cost paid with PBFA funds.

The following distribution is provided for energy and demand impacts:

PBFA (Public Benefit Fee Administrator)	25%
ARRA (American Recovery and Reinvestment Act)	75%

2065 kWh/year 0.46 kW

Pre-Bonus Period (11/1/10 - 3/21/11))	PBF				ARRA			
						Energy Savings	Demand Savings			Energy Savings	Demand Savings
	Unit Incentive	Incremental (Cost	Unit Incentive	% Contribution	(kWh/year)	(kW)	Unit Incentive	% Contribution	(kWh/year)	(kW)
Military	\$ 1,000	\$ 4,	400	\$ 250	25%	516	0.12	\$ 750	75%	1549	0.35
Non-Military	\$ 1,000	\$6,	600	\$ 250	25%	516	0.12	\$ 750	75%	1549	0.35

Bonus Period (3/22/11 - 6/30/11)					PBF				ARRA			
							Energy Savings	Demand Savings			Energy Savings	Demand Savings
	Unit Incer	ntive	Incren	nental Cost	Unit Incentive	% Contribution	(kWh/year)	(kW)	Unit Incentiv	% Contribution	(kWh/year)	(kW)
Military	\$	1,750	\$	4,400	\$ 250	14%	295	0.07	\$ 1,50	86%	1770	0.39
Non-Military	\$	1,750	\$	6,600	\$ 250	14%	295	0.07	\$ 1,50	86%	1770	0.39

Component Costs and Lifetimes Used in Computing O&M Savings TBD

Reference Tables

None



Program Year 3 July 2011 to June 2012

8.1.3 Solar Water Heater Energy Hero Gift Packs

Measure ID:

Version Date & Revision History Draft date: October 4, 2011 Effective date: July 1, 2011 End date: June 30, 2012

Referenced Documents:

- Energy and Peak Demand Impact Evaluation Report of the 2005-2007
- Demand Management Programs KEMA (KEMA 2005-07)
- Econorthwest TRM Review 6/23/10
- Energy and Peak Demand Impact Evaluation Report of the 2005-2007 Demand Management Programs – (KEMA 2005-07)
- Evergreen TRM Review 2/23/12

TRM Review Actions:

• 10/5/11 – Currently Under Review.

Major Changes:

- 11/22/11 LED algorithm updated. See section 8.2.2 for changes.
- 11/22/11 Akamai Power Strip kWh savings updated based on NYSERDA Measure Characterization for Advanced Power Strips.
- 11/22/11 Updated content in headings *Description*, *Base Case*, *High Efficiency Case*, and *Energy Savings* in regard to LED lamps to match section 8.2.2.
- 11/29/11 Low Flow Shower Head algorithm updated previously claiming only 50% of total energy savings due to inaccurately calculating hot and cold water mix. Also updated *Energy Savings* table as necessary.
- 4/17/12 Updated CFL and LED algorithms to refer to CFL and LED sections in TRM to ensure accuracy. Updated energy savings numbers to be consistent with EMV revisions.
- 8/1/12 Updated Low Flow Shower Head algorithm to reduce demand savings from 40% to 20% as per EM&V review (Feb. 2012)

Description:

Potential gift pack components:

- Compact Fluorescent Lamp
- Akamai Power Strip
- LED Lamp
- Low Flow Shower Head

Base Case

- 60 W incandescent lamps
- Standard power strip or no power strip
- 25% 60W incandescent, 25% 40W incandescent, 25% 23W CFLs and 25% 13W CFLs (See LED TRM)
- Low Flow Shower Head rated at 2.5 gpm

High Efficiency Case

- 15W CFLs
- Akamai Power Strip
- 50% 7W LED Lamp and 50% 12.5W LED Lamp
- Low Flow Shower Head rated at 1.5 gpm

ATTACHMENT 3

ENERGY STAR - SAVE MONEY AND MORE WITH ENERGY STAR QUALIFIED SOLAR WATER HEATERS



Save Money and More with ENERGY STAR Qualified Solar Water Heaters

An ENERGY STAR qualified solar water heating system can cut your annual hot water costs in half, and is generally designed for use with an electric or gas back-up water heater. Demonstrate your environmental leadership by voting with your wallet for renewable energy solutions. Purchase an ENERGY STAR qualified solar water heater for your home and enjoy these benefits: **Save money.** By using sunshine to heat or preheat your water, you can cut your water heating bill in half. This means you can save \$190 annually if you combine solar with a backup gas-storage water heater instead of using the gas water heater alone. If you have an electric tank water heater for back-up, you'll save about \$250 each year on electricity bills. Large families with greater hot water needs can save even more.

Invest in a better environment. Water heated by the sun just feels better. The purchase of a solar system can take about 10 years to pay for itself, but by taking advantage of Federal tax credits you can recoup the price premium more quickly. In the meantime, your investment will pay dividends for the environment. ENERGY STAR qualified solar water heaters can cut your carbon dioxide emissions in half. Installing a qualified solar water heater will reduce the load of your electric water heater by almost 2,500 kWh per year, preventing 4,000 pounds of carbon dioxide from entering the atmosphere annually. This is the equivalent of not driving your car for four months every year!

Long lifetime. The average life expectancy of qualified solar water heating systems is 20 years, much longer than standard gas or electric storage water heaters.





Publications Partner Resources Kids Buildings & Plants Site Index Recursos en Español New Homes Flash Viewer PowerPoint Viewer Excel Viewer Home Improvement Privacy Contact Us Products About ENERGY STAR FAQs News Room PDF Viewer



EPA Home EPA Search



DOE Home DOE Search

Share Share / Save

ATTACHMENT 4

SAYING MAHALO TO SOLAR SAVINGS: A BILLING ANALYSIS OF SOLAR WATER HEATERS IN HAWAII

Saying Mahalo to Solar Savings: A Billing Analysis of Solar Water Heaters in Hawaii

Jenny Yaillen, Evergreen Economics Chris Ann Dickerson, CAD Consulting Wendy Takanish and John Cole, Hawaii Public Utilities Commission

ABSTRACT

Over the last several years, the market share for solar water heaters has steadily increased in the state of Hawaii. The Hawaiian government mandated that all new homes have solar water heaters installed, and the state offers incentives to homeowners who opt to purchase solar water heaters for their existing homes. The evaluation of savings and market conditions associated with this equipment is important as other markets consider the energy savings potential of solar water heating technology. This paper provides the results of a billing analysis used to estimate savings of residential solar water heaters in the state of Hawaii and feedback from consumers and contractors on the remaining potential.

The billing analysis was conducted with a monthly panel data regression model using utility billing data and program tracking data for 2,457 customers who installed solar water heaters during program year 2009, estimating changes in household electricity consumption between the pre- and post-installation periods.

The results of this paper are significant because they help provide an updated savings value for solar water heaters in Hawaii and give a current assessment of market conditions. While Hawaii's climate is unique, these savings and market findings can assist other regions in tapping solar water heater potential in their markets. These results will be of interest to other states with sunny climates that have a high solar energy potential.

Introduction, Background, and Summary of Findings

This paper presents the results of a solar water heater billing analysis conducted as part of a larger evaluation of Hawaii Energy's conservation and efficiency programs. The analysis focused on the residential installation of solar water heaters for the program year 2009 (PY2009) and 2010 (PY2010).¹ This paper also presents some findings on the condition of the market for solar water heaters in Hawaii.

The Hawaiian market for solar energy efficiency equipment is somewhat different from the rest of the country. To start, Hawaii's climate and abundance of sunshine make it an ideal locale for the success of a measure like solar water heaters. In addition, the high energy prices that Hawaiian consumers face provide even more reason to invest in a technology like solar water heating.

Interest in solar water heating and renewable energy as a whole has a long history in Hawaii. As early as 1976, Hawaii provided energy tax credits for residents and businesses that purchased and installed renewable energy systems, including solar water heaters. In 1996 a

¹ Hawaii Energy's program year runs from July 1 to June 30. For example, program year 2009 refers to program activities undertaken between July 1, 2009 and June 30, 2010.

rebate was made available through the public benefit fund of Hawaii Energy Efficiency Programs. The public benefits fund was originally collected and administered by Hawaii Electric Company (HECO) and Maui Electric Company (MECO). Since 2009, the energy efficiency programs and rebates have been administered through Hawaii Energy. Rebates for solar water heaters are currently funded by the public benefits fee paid into by ratepayers along with some funding from the American Recovery and Reinvestment Act (ARRA).

Hawaii Energy is a third-party organization that implements conservation and energy efficiency programs throughout Hawaii. They operate a portfolio of programs that cover the residential and commercial sectors, with some programs targeted specifically toward new construction and residential low-income customers. The solar water heater program is currently a part of their residential program offerings. The last time these programs were evaluated was in 2008 when KEMA, Inc. conducted an impact evaluation of the 2005-2007 program cycle of the residential and commercial portfolio.

Our analysis focused on the solar water heater program since coming under the control of Hawaii Energy in 2009. Total solar water heater program participation for PY2009 and PY2010 is shown in Table 1. In our final model, participants from PY2010 are used as a control group to determine the savings realized by PY2009 participants, as the PY2010 participants had not yet installed the solar water heater in 2009 (the year used for the billing analysis). Including the PY2010 customers in the sample provides an additional control for external influences (e.g., economic conditions, household and structural changes) that may impact energy use.

Program Year	Number of Participants
2009	3,607
2010	2,695
Total	6,302

Table 1. Solar Water Heater Participants

The annual savings estimate for solar water heaters found as a result of this analysis is shown below in Table 2, along with a 95 percent confidence interval. Our impact estimate of 1,912 kWh is close to the current ex ante savings value of 2,066 kWh included in the Hawaii Energy PY2010 Technical Reference Manual (TRM).² Given that the savings estimates are so close, we did not recommend any change to the TRM value currently in use by the program.

Table 2. Savings Estimate and 95% Confidence Interval							
Annual Savings 95 % Conf. Interval 95 % Conf. Interval Current TRM Valu							
(kWh)	LOWER BOUND	UPPER BOUND	(kWh)				
1,912	1,714	2,111	2,066				

Source: Analysis by Evergreen Economics of data provided by Hawaii Energy

² The PY2010 TRM savings value of 2,066 kWh is based on the 2008 evaluation by KEMA Inc. of the 2005-2007 Hawaii demand side management programs, which included a solar hot water heater metering study.

Billing Regression

For the billing regression, we developed a fixed effects billing regression model using monthly panel data to estimate changes in household electricity consumption between the baseline ("pre") and post-measure-installation periods. The billing regression model relates normalized monthly electricity consumption by household by month to:

- 1. An indicator variable for the months in which the solar water heater was installed
- 2. Monthly dummy variables to control for external factors³
- 3. Interaction terms between the indicator for solar water heater installation and monthly dummy variables

Interactions between the first two independent variables were examined and ultimately included in the model. The final model was estimated using the linear values of the dependent and independent variables.⁴ While a number of different specifications were explored, the final fixed effects model was specified as follows:

 $kWh_{ii} = \beta_0 + \beta_1 SWH_{ii} + \beta_2 Month_{ii} + \beta_3 Month_{ii} * SWH_{ii} + e_{ii}$ Where: kWh = Normalized monthly electricity consumption for each month (in kWh) SWH = Indicator variable for post-period solar water heater installation period Month = Indicator variables for each month excluding December Month * SWH = Interaction terms between indicator for post-period solar water heater installation and monthly indicators i = Index for household (i = 1,..., n) t = Index for monthly time period (t=1,2,..., T) $[\beta_0,...,\beta_3,] = \text{Coefficients to be estimated in the model}$ [e] = Error term assummed normally distributed

Data Used in Analysis

Monthly electricity billing data and information related to the timing of solar water heater installation were provided by Hawaii Energy for participants in program years 2009 and 2010. Utility billing data were provided from April 2008 to July 2011.

Weather or temperature data were not included in this analysis since water heater use is not greatly affected by daily outdoor temperature and temperatures are relatively constant throughout the year in Hawaii. However, monthly indicator variables were included in the final

³ December was excluded to avoid perfect collinearity between independent variables.

⁴ As opposed to the alternative of first transforming the dependent variable and/or the independent variables by the natural log function.

model specification to capture any seasonal or monthly effects that may exist. Variables included in the billing regression model are defined below in

Table 3.

Variable	Description
kWh	Normalized monthly electricity consumption by month (calculated by scaling
	usage from number of meter read days to the average number of days per month)
SWH	Indicator variable for months after solar water heater installation (equals 1 if in
	post-installation period; else equals 0)
Month	A vector of indicator variables for month of year (equals 1 if observation falls in
(January, February,	that month; else equals 0)
March, etc.)	
Month_SWH	A vector of indicator variables for month of year and solar water heater
(Jan_SWH,	installation (equals 1 if in post-installation period and observation falls in that
Feb_SWH,	month; else equals 0)
Mar SWH, etc.)	

Table 3. Description of Model Variables

Data screens were employed to ensure that only participants within a reasonable consumption range were included in the analysis. This data screen was based on monthly kWh usage and participants were selected for analysis if their monthly usage fell between 50 and 3,000 kWh. The effect of implementing this screen on the data is shown in Table 4 below.

Table 4. Summary of Data Screens								
Program Year	Total Participants	Participants with Billing Data	Participants Meeting kWh Criteria					
2009	3,607	3,606	2,457					
2010	2,695	2,693	1,951					
Total	6,302	6,299	4,408					

Table 4. Summary of Data Screens

Source: Analysis by Evergreen Economics of data provided by Hawaii Energy

This data screen was used in the final model presented in this paper. Column four of Table 4 shows the number of individual participants included in the final model. Pre- and post-installation data were included for all 2,457 PY2009 participants shown in this table. The 1,951 participants from PY2010 were included as a control group, and as such only their pre-installation billing data were included in the analysis.

Billing Model Estimation Results

The results from the billing regression model are shown below in Table 5. All of the estimated coefficients are of the expected sign (either negative or positive) and the primary variable of interest (SWH) is statistically significant at the 5 percent level. About half of the monthly indicator variables are statistically significant at the 5 percent level as well. The coefficients on monthly indicators and interaction terms show that kWh usage varies by month, with February, March, April, and May showing statistically significant lower usage per month, on average, than December (the omitted variable).

The coefficient of interest with respect to solar water heater energy savings is β_1 (the coefficient on the post-installation indicator). This coefficient is negative, indicating that, after accounting for monthly variations in electricity usage and holding all else constant, participants experienced an estimated base decrease of 159.37 kWh per month after installation of a solar water heater. This translates to an annual savings of 1,912 kWh due to the solar water heater installation.

Note that this result captures all changes in usage in the post period and attributes them to the solar water heater installation. To the extent that there are external influences that are reducing energy use outside the program and are not controlled for in our model, then the savings estimates derived from the model will overstate the actual energy savings of the solar water heaters.

Variable	Coefficient	Std. Error	t-statistic	p-value
(β_0) Constant	845.62	4.56	185.59	0.00
(β_1) SWH	-159.37	8.43	-18.90	0.00
(β_2) January	13.14	6.56	2.00	0.05
(β_2) February	-27.05	6.79	-3.98	0.00
(β_2) March	-33.46	6.63	-5.04	0.00
(β_2) April	-39.69	6.86	-5.78	0.00
(β_2) May	-33.50	7.04	-4.76	0.00
(β_2) June	-7.60	6.23	-1.22	0.22
(β_2) July	-1.12	6.24	-0.18	0.86
(β_2) August	11.26	6.32	1.78	0.08
(β_2) September	7.61	6.31	1.21	0.23
(β_2) October	1.69	6.38	0.27	0.79
(β_2) November	4.93	6.57	0.75	0.45
(β_3) January_SWH	8.37	11.77	0.71	0.48
(β_3) February_SWH	-6.30	12.06	-0.52	0.60
(β ₃) March_SWH	4.81	11.45	0.42	0.68
(β ₃) April_SWH	-7.80	11.82	-0.66	0.51
(β ₃) May_SWH	5.20	11.82	0.44	0.66
(β ₃) June_SWH	-10.30	11.17	-0.92	0.36
(β ₃) July_SWH	-1.37	11.28	-0.12	0.90
(β_3) August_SWH	-2.33	12.51	-0.19	0.85
(β ₃) September_SWH	-0.16	12.25	-0.01	0.99
(β ₃) October_SWH	6.43	12.26	0.52	0.60
(β ₃) November_SWH	4.54	12.31	0.37	0.71

Table 5. Regression Results

Source: Analysis by Evergreen Economics of data provided by Hawaii Energy

The coefficient on SWH (β_1) in Table 5 above was used to calculate the annual savings attributable to solar water heaters. The data used in the model was on a monthly basis, so the coefficient estimate of -159.37 indicates that an average of 159.37 kWh in savings were realized in each month that a solar water heater was installed. To get an annual savings value, this number was simply multiplied by 12. The formula used to calculate annual savings is shown below:

Estimated change in annual energy use due to Solar Water Heater = Coefficient on SWH * 12

Table 6 below shows the estimated annual savings for solar water heaters installed by PY2009 participants along with a 95 percent confidence interval and the existing savings value in Hawaii Energy's PY2010 Technical Reference Manual (TRM).

	is negression savings	Estimate and 5570 Co	muchec mee var
Annual Savings (kWh)	95 % Conf. Interval LOWER BOUND	95 % Conf. Interval UPPER BOUND	2010 TRM Savings (kWh)
1,912	1,714	2,111	2,066

 Table 6. Billing Regression Savings Estimate and 95% Confidence Interval

Source: Analysis by Evergreen Economics of data provided by Hawaii Energy

Comparison to Existing Savings Values

These billing regression results are slightly lower than, although generally consistent with, the savings value calculated in the PY2010 TRM. The TRM value for solar water heater savings is 2,066 kWh annually and assumes an average household occupancy of 3.77 people. The average household occupancy reported by the surveyed PY2009 participants was 3.53, which is slightly lower than that assumed by the TRM. A lower occupancy is generally associated with less hot water use and consequently these households may see slightly smaller annual savings than the TRM suggests.

In addition, the annual kWh consumption of the sample households is lower than the average found in earlier solar water heater impact evaluations. The average annual base consumption in the model data was 10,147 kWh, whereas the annual base consumption found in the 2001-03 Impact Evaluation prepared by KEMA was 11,096 kWh. The kWh savings reported by KEMA for solar water heaters in that report was 2,201 kWh. The small difference in occupancy and base consumption between these groups may explain some of the difference in savings found by our analysis. Despite these differences, the TRM savings value of 2,066 kWh does fall within the 95 percent confidence interval of our estimated savings, indicating that our analysis confirms the existing value for solar water heaters.

Solar Water Heater Market Findings

The solar water heating market provides considerable opportunity for energy savings in Hawaii. Based on the findings in this analysis, installed residential solar water heaters can save the average Hawaii household nearly 20 percent on their annual electric bill, which is equivalent to about \$500 to \$700 annually, depending on the electricity rate for each island.⁵ The expected lifetime of a solar water heater is 15 years, and the savings will persist over that time. These savings have been significant enough that the Hawaii State Senate passed SB no. 644, which requires all new single-family residences constructed after January 1, 2010 to include a solar water heater system. Despite this requirement for new residential homes, there is still a large market for retrofitting solar water heaters in existing homes. The current estimates are that roughly 75 percent of homes in Hawaii do not have a solar water heater system.

The Hawaii Energy solar water heater program recently transitioned its focus to retrofitted solar water heating systems in order to comply with the new Senate Bill that mandated solar water heating on all new homes. The retrofit market often consists of those customers that

⁵ Average residential electricity rates in Hawaii for 2010 varied from \$0.2547 on Oahu to \$0.3711 on Lanai.

are the most difficult and costly to serve and, as a result, the incentive program is even more vital to installations of solar water heaters for this market segment. The incremental cost of a solar water heater is listed as \$6,600 in the PY2010 TRM and has a rebate amount of \$750. The additional electricity cost savings provided by the solar water heater adds an extra incentive for retrofit customers.

At the end of 2009 there was a significant rush of solar water heater installations by new construction builders and customers in order to take advantage of the rebate before the expiration date. There was also an initial boost in install rates at the beginning of the 2010 program year, and again at the end of calendar year 2010. In March 2011, Hawaii Energy was approved to use ARRA funding to double the cash rebate amount for solar water heater systems, which resulted in 800 systems being sold in one month and completely exhausting the additional approved funds.

The current solar water heater program is strong, and interviews with solar water heater contractors reveal that they see it as a reliable technology, which requires little more than routine maintenance. To assist in this routine maintenance, Hawaii Energy has started offering a rebate for solar water heater tune-ups in PY2011 at a cost of \$250 to participants after a \$50 rebate. In addition to contractor satisfaction with the equipment, participant surveys revealed that 97 percent of PY2009 participants and 96 percent of PY2010 participants were "somewhat satisfied" or "very satisfied" with their solar water heater purchase. Together these two results indicate that solar water heaters have a positive market presence in Hawaii.

Summary and Conclusions

Using a billing regression model and a sample of 2009 and 2010 solar water heater participants, we estimated annual savings from this measure of 1,912 kWh. This generally confirms the savings value of 2,066 kWh in use by Hawaii Energy for PY2010, as that value lies within the 95 percent confidence interval of our savings estimate. The slight difference may be explained by lower occupancy rates and/or lower household energy consumption in our analysis sample relative to the values found in previous impact evaluations. For these reasons, we did not recommend any changes to the current *ex ante* value of 2,066 kWh used by Hawaii Energy for solar water heaters.

The market for solar water heaters in Hawaii now relies heavily on retrofitting water heating systems in existing homes due to the recent legislation requiring solar water heaters in all new construction projects. Our research found that there is still considerable potential in the retrofit market, and that incentives can be a substantial driver toward replacement. Additionally, interviews with contractors revealed that solar water heaters are a reliable technology that requires little maintenance and surveys of participants revealed high satisfaction rates with the installed equipment.

References

Hawaii Energy. 2011. Technical Reference Manual (TRM) No. 2010-1. Honolulu, HI.

Hawaii Energy. 2011. Technical Reference Manual (TRM) No. 2011. Honolulu, HI.

Hawaiian Electric Company. Average Electric Rates for Hawaiian Electric Co., Maui Electric Co. and Hawaii Electric Light Co.

http://www.heco.com/portal/site/heco/menuitem.508576f78baa14340b4c0610c510b1ca/? vgnextoid=692e5e658e0fc010VgnVCM1000008119fea9RCRD&vgnextchannel=106293 49798b4110VgnVCM1000005c011bacRCRD&vgnextfmt=default&vgnextrefresh=1&le vel=0&ct=article

- KEMA, Inc. 2008. Energy and Peak Demand Impact Evaluation Report of the 2005-2007 Demand Side Management Programs. Oakland, CA.
- KEMA-XENERGY, Inc. 2004. Energy and Peak Demand Impact Evaluation Report of the 2001-2003 Demand Side Management Programs. Oakland, CA.

ATTACHMENT 5

EPA COMBINED HEAT AND POWER PARTNERSHIP FUEL AND CARBON DIOXIDE EMISSIONS SAVINGS CALCULATION METHODOLOGY FOR COMBINED HEAT AND POWER SYSTEMS, AUGUST 2012





Fuel and Carbon Dioxide Emissions Savings Calculation Methodology for Combined Heat and Power Systems

U.S. Environmental Protection Agency

Combined Heat and Power Partnership

August 2012

The U.S. Environmental Protection Agency (EPA) CHP Partnership is a voluntary program that seeks to reduce the environmental impact of power generation by promoting the use of CHP. The CHP Partnership works closely with energy users, the CHP industry, state and local governments, and other stakeholders to support the development of new CHP projects and promote their energy, environmental, and economic benefits.

The CHP Partnership provides resources about CHP technologies, incentives, emissions profiles, and other information on its website at <u>www.epa.gov/chp</u>. For more information, contact the CHP Partnership Helpline at <u>chp@epa.gov</u> or (703) 373-8108.

Table of Contents

1.0 Introduction	1
2.0 What Is CHP?	3
2.1 How CHP Systems Save Fuel and Reduce CO ₂ Emissions	4
3.0 Calculating Fuel and CO ₂ Emissions Savings from CHP	6
3.1 Fuel Use and CO ₂ Emissions from Displaced On-site Thermal Production and Displaced Grid Electricity	7
3.1.1 Fuel Use and CO ₂ Emissions from Displaced On-site Thermal Production	7
3.1.2 Fuel Use and CO ₂ Emissions from Displaced Grid Electricity	9
3.2 Fuel Use and CO_2 Emissions of the CHP System	10
Appendix A: EPA CHP Emissions Calculator Example Calculation	13
Appendix B: Displaced Grid Electricity Fuel Use and CO ₂ Emissions	20

1.0 Introduction

Amid growing concerns about energy security, energy prices, economic competitiveness, and climate change, combined heat and power (CHP) has been recognized for its significant benefits and the part it can play in efficiently meeting society's growing energy demands while reducing environmental impacts. Policy makers, project developers, end users, and other CHP stakeholders often need to quantify the fuel and carbon dioxide (CO₂) emissions savings of CHP projects compared to conventional separate heat and power (SHP) in order to estimate projects' actual emissions reductions. An appropriate quantification of the energy and CO₂ emissions savings from CHP plays a critical role in defining its value proposition. At this time, there is no established methodology to quantify and make this estimation.

This paper provides the EPA Combined Heat and Power Partnership's (the Partnership) recommended methodology for calculating fuel and CO₂ emissions savings from CHP compared to SHP.¹ This methodology recognizes the multiple outputs of CHP systems and compares the fuel use and emissions of the CHP system to the fuel use and emissions that would have normally occurred in providing energy services through SHP.

Although the methodology recommended in this paper is useful for the specific purposes mentioned above, it is not intended as a substitute

Summary of Key Points

- To calculate the fuel and CO₂ emissions savings of a CHP system, both electric and thermal outputs of the CHP system must be accounted for.
- The CHP system's thermal output displaces the fuel normally consumed in and emissions emitted from on-site thermal generation in a boiler or other equipment, and the power output displaces the fuel consumed and emissions from grid electricity.
- To quantify the fuel and CO₂ emissions savings of a CHP system, the fuel use of and emissions released from the CHP system are subtracted from the fuel use and emissions that would normally occur without the system (i.e., using SHP).
- A key factor in estimating the fuel and CO₂ emissions savings for CHP is determining the heat rate and emissions factor of the displaced grid electricity. EPA's Emissions & Generation Resource Integrated Database (eGRID) is the recommended source for these factors. See Appendix B for information about these inputs.

methodology for organizations quantifying and reporting GHG inventories. EPA recommends that organizations use accepted GHG protocols, such as the World Resources Institute's Greenhouse Gas Protocol² or The Climate Registry's General Reporting Protocol³, when calculating and reporting a company's carbon footprint.

However, the CO_2 emissions savings amounts estimated using the methodology recommended in this paper can be reported as supplemental information in an organization's public disclosure of its GHG inventory in order to help inform stakeholders of the emissions benefits of CHP and to highlight the organization's commitment to energy-efficient and climate-friendly technologies.

¹ CHP can also reduce emissions of methane and nitrous oxide along with other air pollutants. Although methane and nitrous oxide are not discussed in this paper they are accounted for in the CHP Emissions Calculator. The CHP Emissions Calculator is available at: <u>http://www.epa.gov/chp/basic/calculator.html</u>.

² The Greenhouse Gas Protocol is available at: <u>http://www.ghgprotocol.org/</u>.

³ The Climate Registry General Reporting Protocol is available at: <u>http://www.theclimateregistry.org/resources/protocols/general-reporting-protocol/</u>.

The paper is organized as follows:

- Section 2 introduces CHP and explains the basis for fuel and CO₂ emissions savings from CHP compared to SHP.
- Section 3 presents a methodology for calculating the fuel and CO₂ emissions savings from CHP.
- Appendix A presents a sample calculation of fuel and CO₂ emissions savings using the EPA CHP Emissions Calculator.⁴
- Appendix B explains the use of EPA's Emissions & Generation Resource Integrated Database (eGRID) as a source for two important variables in the calculation of fuel and CO₂ emissions savings from displaced grid electricity: displaced grid electricity heat rate⁵ and CO₂ emissions factors. It also describes how to select values for these variables.

⁴ The EPA CHP Emissions Calculator is available at: <u>http://www.epa.gov/chp/basic/calculator.html</u>.

⁵ Heat rate is the ratio of fuel energy input as heat (Btu) per unit of net power output (kWh).

2.0 What Is CHP?

Combined heat and power (CHP) is a highly efficient method of providing power and useful thermal energy (heating or cooling) at the point of use with a single fuel source. By employing waste heat recovery technology to capture a significant portion of the heat created as a by-product of fuel use, CHP systems typically achieve total system efficiencies of 60 to 80 percent. An industrial or commercial entity can use CHP to produce electricity and thermal energy instead of obtaining electricity from the grid and producing thermal energy in an on-site furnace or boiler. In this way, CHP can provide significant energy efficiency, cost savings, and environmental benefits compared to the combination of grid-supplied electricity and on-site boiler use (referred to as separate heat and power or SHP).

CHP plays important roles both in efficiently meeting U.S. energy needs and in reducing the environmental impact of power generation. Currently, CHP systems represent approximately 8 percent of the electric generating capacity in the United States.⁶ Benefits of CHP include:

- Efficiency benefits: CHP requires less fuel than SHP to produce a given energy output, and because electricity is generated at the point of use, transmission and distribution losses that occur when electricity travels over power lines from central power plants are displaced.
- **Reliability benefits:** CHP can be designed to provide high-quality electricity and thermal energy on site without relying on the electric grid, decreasing the impact of outages and improving power quality for sensitive equipment.
- Environmental benefits: Because less fuel is burned to produce each unit of energy output, CHP reduces emissions of greenhouse gases (GHG) and other air pollutants.
- **Economic benefits:** Because of its efficiency benefits, CHP can help facilities save money on energy. Also, CHP can provide a hedge against fluctuations in electricity costs.

In the most common type of CHP system, known as a topping cycle (see Figure 1), fuel is used by a prime mover⁷ to drive a generator to produce electricity, and the otherwise-wasted heat from the prime mover is recovered to provide useful thermal energy. Examples of the two most common topping cycle CHP configurations are:

- A reciprocating engine or gas turbine burns fuel to generate electricity and a heat recovery unit captures heat from the exhaust and cooling system. The recovered heat is converted into useful thermal energy, usually in the form of steam or hot water.
- A steam turbine uses high-pressure steam from a fired boiler to drive a generator producing electricity. Low-pressure steam extracted from or exiting the steam turbine is used for industrial processes, space heating or cooling, domestic hot water, or for other purposes.

⁶ *CHP Installation Database* developed by ICF International for Oak Ridge National Laboratory and the U.S. DOE; 2012. Available at http://www.eea-inc.com/chpdata/index.html.

⁷ Prime movers are the devices (e.g., reciprocating engine, gas turbine, microturbine, steam turbine) that convert fuels to electrical energy via a generator.



Figure 1: Typical Reciprocating Engine/Gas Turbine CHP Configuration (Topping Cycle)

In another type of CHP system, known as a bottoming cycle, fuel is used for the purpose of providing thermal energy in an industrial process, such as a furnace, and heat from the process that would otherwise be wasted is used to generate power.

2.1 How CHP Systems Save Fuel and Reduce CO₂ Emissions

CHP's efficiency benefits result in reduced primary energy⁸ use and thus lower CO₂ emissions.

Figure 2 shows the efficiency advantage of CHP compared to SHP.⁹ CHP systems typically achieve total system efficiencies of 60 to 80 percent compared to about 45 to 55 percent for SHP. As shown in Figure 2, CHP systems not only reduce the amount of total fuel required to provide electricity and thermal energy, but also shift where that fuel is used. Installing a CHP system on site will generally increase the amount of fuel that is used at the site, because additional fuel is required to operate the CHP system compared to the equipment that otherwise would have been used on site to produce needed thermal energy.

In the example shown in Figure 2, the on-site fuel use increases from 56 units in the SHP case to 100 units in the CHP case. However, despite this increase in on-site fuel use, the total fuel used to provide the facility with the required electrical and thermal energy drops from 147 units in the SHP case, to 100 units in the CHP case, a 32 percent decrease in the amount of total fuel used.

⁸ Primary energy is the fuel that is consumed to create heat and/or electricity.

⁹ Like Figure 1, Figures 2 and 3 illustrate the most common CHP configuration known as the topping cycle. See section 2.0 for more information.

Figure 2: Energy Efficiency - CHP Versus Separate Heat and Power (SHP) Production (Topping Cycle)



Note: Conventional power plant delivered efficiency of 33% (higher heating value [HHV]) is based on eGRID 2012 (2009 data) and reflects the national average all fossil generating efficiency of 35.6% and 7% transmission and distribution losses. eGRID provides information on emissions and fuel resource mix for individual power plants, generating companies, states, and subregions of the power grid. eGRID is available at <u>http://www.epa.gov/cleanenergy/energy-resources/egrid/index.html</u>.

Using less fuel to provide the same amount of energy reduces CO_2 and other emissions. Figure 3 shows the annual CO_2 emissions savings of a natural gas combustion turbine CHP system compared to SHP. In this case, the CHP system produces about half the annual CO_2 emissions of SHP while providing the same amount of energy to the user.

Figure 3: CO₂ Emissions - CHP Versus Separate Heat and Power (SHP) Production (Topping Cycle)



Note: Emissions savings are based on the efficiencies included in Figure 2 for SHP and a 5 MW gas turbine CHP system and 7,000 annual operating hours. Power plant CO₂ emissions are based on eGRID 2012 national all fossil generation average (2009 data).

3.0 Calculating Fuel and CO₂ Emissions Savings from CHP

To calculate the fuel or CO₂ emissions savings of a CHP system, both outputs of the CHP system thermal energy and electricity—must be accounted for. The CHP system's thermal output typically displaces the fuel otherwise consumed in an on-site boiler, and the electric output displaces fuel consumed at central station power plants.¹⁰ Moreover, the CHP system's electric output also displaces fuel consumed to produce electricity lost during transmission and distribution.

The displaced fuel use and CO_2 emissions associated with the operation of a CHP system can be determined by:

a. Calculating the fuel use and emissions from displaced separate heat and power (SHP) (i.e., grid-supplied electricity and on-site thermal generation such as a boiler)

- b. Calculating the fuel use and emissions from CHP
- c. Subtracting (b) from (a)

Equation 1 presents the recommended approach for calculating the fuel savings of a CHP system. Equation 2 presents the recommended approach for calculating CO_2 emissions savings of a CHP system.

<u>Note</u>: Sections 3.1 and 3.2 present the approaches for calculating the individual terms found in Equations 1 and 2. Appendix A presents a sample calculation of CO_2 savings using the EPA CHP Emissions Calculator which uses the methodology and equations outlined in this section.

Equation 1: Calculating Fuel Savings from CHP

 $F_S = (F_T + F_G) - F_{CHP}$

where:

- F_S = Total Fuel Savings (Btu)
- F_T = Fuel Use from Displaced On-site Thermal Production (Btu)
- F_G = Fuel Use from Displaced Grid Electricity (Btu)
- F_{CHP} = Fuel Used by the CHP System (Btu)

Step 1: Calculate F_T and F_G using Equation 3 (page 8) and Equation 6 (page 10), respectively.

Step 2: Calculate F_{CHP} through direct measurement or using Equations 8 (page 11), 9 (page 11) or 10 (page 12).

Step 3: Calculate F_S.

¹⁰ The thermal output from CHP can also be used to produce cooling in an absorption or adsorption chiller. Accounting for cooling introduces complexities that are not addressed in the methodology presented in this paper. However, the CHP Emissions Calculator does account for cooling.

Equation 2: Calculating CO₂ Savings from CHP

 $C_S = (C_T + C_G) - C_{CHP}$

where:

- C_{S} = Total CO₂ Emissions Savings (lbs CO₂)
- C_T = CO₂ Emissions from Displaced On-site Thermal Production (lbs CO₂)
- C_G = CO₂ Emissions from Displaced Grid Electricity (lbs CO₂)
- $C_{CHP} = CO_2$ Emissions from the CHP System (lbs CO_2)

Step 1: Calculate C_T and C_G using Equation 4 (page 8) and Equation 7 (page 10), respectively.

Step 2: Calculate C_{CHP} using Equation 11 (page 12).

Step 3: Calculate C_S.

<u>Note on using Equations 1 and 2 for bottoming cycle CHP systems</u>: In the case of bottoming cycle CHP, also known as waste heat to power, power is generated on site from the hot exhaust of a furnace or kiln with no additional fuel requirement. Therefore, the fuel use and CO_2 emissions for both the CHP system and displaced thermal energy (F_{CHP} , C_{CHP} , F_T , and C_T) are all zero.

3.1 Fuel Use and CO₂ Emissions from Displaced On-site Thermal Production and Displaced Grid Electricity

3.1.1 Fuel Use and CO₂ Emissions from Displaced On-site Thermal Production

The thermal energy produced by a CHP system displaces combustion of some or all of the fuel that would otherwise be consumed for on-site production of thermal energy.¹¹ The fuel and CO₂ emissions savings associated with this displaced fuel consumption can be calculated using the thermal output of the CHP system and reasonable assumptions about the efficiency characteristics of the equipment that would otherwise have been used to produce the thermal energy being produced by the CHP system. Equation 3 presents the approach for calculating the fuel use from displaced on-site thermal production. Equation 4 presents the approach for calculating the CO₂ emissions from displaced on-site thermal production. Table 1 lists selected fuel-specific CO₂ emissions factors for use in Equation 4.

¹¹ In certain circumstances, CHP systems are designed so that supplemental on-site thermal energy production is sometimes utilized.
$F_T = CHP_T / \eta_T$

where:

Fτ	=	Fuel Use from Displaced On-site Thermal Production (Btu)
CHPT	=	CHP System Thermal Output (Btu)
ŋ⊤	=	Estimated Efficiency of the Thermal Equipment (percentage in decimal form)

Step 1: Measure or estimate CHP_T.

Step 2: Select η_T (e.g., 80% efficiency for a natural gas-fired boiler, 75% for a biomass-fired boiler).

Step 3: Calculate F_T.

Equation 4: Calculating CO₂ Emissions from Displaced On-site Thermal Production

 $C_T = F_T * EF_F * (1x10^{-6})$

where:

CT	=	CO ₂ Emissions from Displaced On-site Thermal Production (lbs CO ₂)
Fτ	=	Thermal Fuel Savings (Btu)
EF _F	=	Fuel Specific CO ₂ Emission Factor (lbs CO ₂ /MMBtu)
1x10⁻ ⁶	=	Conversion factor from Btu to MMBtu

Step 1: Calculate F_T using Equation 3.

Step 2: Select the appropriate EF_F from Table 1.

Step 3: Calculate C_T.

Fuel Type	Energy Density	CO ₂ Emissions Factor, Ib/MMBtu	
Natural Gas	1,028 Btu/scf	116.9	
Distillate Fuel Oil #2	138,000 Btu/gallon	163.1	
Residual Fuel Oil #6	150,000 Btu/gallon	165.6	
Coal (Anthracite)	12,545 Btu/lb	228.3	
Coal (Bituminous)	12,465 Btu/lb	205.9	
Coal (Subbituminous)	8,625 Btu/lb	213.9	
Coal (Lignite)	7,105 Btu/lb	212.5	
Coal (Mixed-Industrial Sector)*	11,175 Btu/lb	207.1	

* This is the default value for coal used in the CHP Emissions Calculator. Users can also manually enter specific factors for type of coal used, if known.

Source: 40 CFR Part 98, Mandatory Greenhouse Gas Reporting, Table C-1: Default CO₂; Emission Factors and High Heat Values for Various Types of Fuel. Available at: http://ecfr.gpoaccess.gov/cgi/t/text/text-

idx?c=ecfr&sid=1e922da1c1055b070807782d1366f3d1&rgn=div9&view=text&node=40:21.0.1.1.3.3. 1.10.18&idno=40.

3.1.2 Fuel Use and CO₂ Emissions from Displaced Grid Electricity

Grid electricity savings associated with on-site CHP include the grid electricity displaced by the CHP output and related transmission and distribution losses.

When electricity is transmitted over power lines, some of the electricity is lost. The amount delivered to users¹² is therefore less than the amount generated at central station power plants, usually by an average of about 6 to 9 percent.^{13,14} Consequently, generating 1 MWh of electricity on site means that more than 1 MWh of electricity no longer needs to be generated at central station power plants.¹⁵ Fuel and CO₂ emissions savings from displaced grid electricity should therefore be based on the corresponding amount of displaced grid electricity generated and not on the amount of grid electricity delivered (and consumed).

Equation 5 presents the approach for calculating the displaced grid electricity from CHP. Once the displaced grid electricity from CHP is determined, the fuel use (Equation 6) and CO_2 emissions (Equation 7) from displaced grid electricity can be calculated.

Note: Key factors needed to calculate the fuel use and CO_2 emissions from displaced grid electricity are the heat rate and CO_2 emissions factor for the grid electricity displaced. EPA's Emissions & Generation Resource Integrated Database (eGRID) is the recommended source for these factors. CHP fuel and CO_2 emissions savings calculations should be based on the heat rates and emissions factors of the eGRID subregion where the CHP system is located, utilizing the eGRID all fossil or non-baseload emissions factors as appropriate. See Appendix B for information about using eGRID.

Equation 5: Calculating Displaced Grid Electricity from CHP

 $E_G = CHP_E / (1-L_{T\&D})$

where:

E _G	=	Displaced Grid Electricity from CHP (kWh)
		CLID System Electricity Output (UM/b)

 $CHP_E = CHP$ System Electricity Output (kWh)

 $L_{T\&D}$ = Transmission and Distribution Losses (percentage in decimal form)

Step 1: Measure or estimate CHP_E.

Step 2: Select $L_{T\&D}$. (Use the eGRID transmission and distribution loss value for the appropriate U.S. interconnect power grid^{*})

Step 3: Calculate E_G.

* eGRID lists the estimated transmission and distribution loss for each of the five U.S. interconnect power grids (i.e., Eastern, Western, ERCOT, Alaska, and Hawaii). (eGRID Technical Support Document: http://www.epa.gov/cleanenergy/documents/egridzips/eGRID2012 year09 Technical SupportDocument.pdf).

¹² For clarity, the amount of electricity generated by a central station power plant is referred to as "generated" electricity and the amount of electricity consumed by a facility supplied by the grid is referred to as "delivered" electricity. ¹³ EPA eGRID Technical Support Document. April 2012.

http://www.epa.gov/cleanenergy/documents/egridzips/eGRID2012_year09_TechnicalSupportDocument.pdf ¹⁴ DOE Energy Information Administration. State Electricity Profiles.

http://205.254.135.24/cneaf/electricity/st_profiles/e_profiles_sum.html

¹⁵ For example, assume a consumer without CHP requires 1.0 MWh of electricity each year and T&D losses equal 8%. The delivered electricity is 1.0 MWh/yr, and the generated electricity is 1.087 MWh/yr (= 1/(1-0.08)).

Equation 6: Calculating Fuel Use from Displaced Grid Electricity

 $F_G = E_G * HR_G$

where:

С

W

C E E

F _G	=	Fuel Use from Displaced Grid Electricity (Btu)
E _G	=	Displaced Grid Electricity from CHP (kWh)
HR_{G}	=	Grid Electricity Heat Rate (Btu/kWh) for the appropriate subregion

Step 1: Determine E_G using Equation 5.

Step 2: Select HR_G for the appropriate subregion. (See Appendix B for information about appropriate values and eGRID as a source for grid electricity heat rates.)

Step 3: Calculate F_G.

		Equation 7: Calculating CO ₂ Emissions from Displaced Grid Electricity
G	=	E _G * EF _G
here:		
G G F _G	= = =	CO ₂ Emissions from Displaced Grid Electricity (lbs CO ₂) Displaced Grid Electricity from CHP (kWh) Grid Electricity Emissions Factor (lbs CO ₂ /kWh) for the appropriate subregion

Step 1: Determine E_G using Equation 5.

Step 2: Select EF_G for the appropriate subregion. (See Appendix B for information about appropriate values and eGRID as a source for grid electricity CO_2 emission factors).

Step 3: Calculate C_G.

3.2 Fuel Use and CO₂ Emissions of the CHP System

The energy content of the fuel consumed by the CHP system (F_{CHP} in Equation 1) can be determined through several methods. Direct measurement (option 1) produces the most accurate results, but if direct measurement is not an option the Partnership recommends the use of options 2, 3, or 4.

- 1) Direct measurement of the higher heating value (HHV) of the fuel consumed (typically in MMBtu_{HHV}). No calculation required.
- 2) Converting the fuel volume into an energy value (Btu equivalent) using a fuel-specific energy density using Equation 8.
- 3) Converting the fuel weight into an energy value (Btu equivalent) using a fuel-specific energy density (mass basis) using Equation 9.
- 4) Applying the electrical efficiency of the CHP system to the CHP system's electric output using Equation 10.

Equation 8: Calculating Energy Content of the Fuel Used by CHP from the Fuel Volume

F_{CHP} V_F * ED_F =

where:

F _{CHP}	=	Fuel Used by the CHP System (Btu)
VF	=	Volume of CHP Fuel Used (cubic foot, gallon, etc.)
ED _F	=	Energy Density of CHP Fuel (Btu/cubic foot, Btu/gallon, etc.)

Step 1: Measure or estimate V_F.

Step 2: Select the appropriate value of ED_F. (See Table 1 on page 8)

Step 3: Calculate F_{CHP}.

Equation 9: Calculating Energy Content of the Fuel Used by CHP from the Fuel Weight

W_F * ED_F F_{CHP} =

where:

F _{CHP}	=	Fuel Used by the CHP System	(Btu)
-------------------------	---	-----------------------------	-------

- Weight of CHP Fuel Used (lbs) WF =
- EDF = Energy Density of CHP Fuel - Mass Basis (Btu/lb)

Step 1: Measure or estimate W_F.

Step 2: Select the appropriate ED_F. In order to be used here, the values in Table 1 (page 8) must be converted to a mass basis using the fuel-specific density.

Step 3: Calculate F_{CHP}.

Equation 10: Calculating Energy Content of the Fuel Used by CHP from the CHP Electric Output

F_{CHP} = (CHP_E / EE_{CHP}) * 3412

where:

- $F_{CHP} = \\ CHP_E = \\ EE_{CHP} =$ Fuel Used by the CHP System (Btu)
- CHP System Electricity Output (kWh)
- Electrical Efficiency of the CHP System (percentage in decimal form)
- Conversion factor between kWh and Btu 3412 =

Step 1: Measure or estimate CHP_F.

Step 2: Determine EE_{CHP}. (This value should account for parasitic losses, and is usually available in a product specification sheet provided by the manufacturer of the equipment.)

Step 3: Calculate F_{CHP}.

The CO₂ emissions from the CHP system are a function of the type and amount of fuel consumed. CO₂ emissions rates are commonly presented as pounds of emissions per million Btu of fuel input (lb/MMBtu). Table 1 on page 8 lists common fuel-specific CO₂ emissions factors. Equation 11 presents the approach for calculating CO₂ emissions from a CHP system (C_{CHP} in Equation 2).

Equation 11: Calculating CO₂ Emissions from the CHP System

 $C_{CHP} = F_{CHP} * EF_F$

where:

C _{CHP} =	CO ₂ Emissions	from the CHP	System	(lbs CO ₂)
--------------------	---------------------------	--------------	--------	------------------------

- F_{CHP} = Fuel Used by the CHP System (Btu)
- EF_F = Fuel Specific Emissions Factor (lbs CO₂ /MMBtu)

Step 1: Measure or calculate F_{CHP} using Equations 8 (page 11), 9 (page 11), or 10 (page 12).

Step 2: Select the appropriate EF_F from Table 1 on page 8.

Step 3: Calculate C_{CHP} the CO₂ emissions from the CHP system.

Appendix A: EPA CHP Emissions Calculator Example Calculation

The Partnership developed the EPA CHP Emissions Calculator to help users calculate the fuel and CO₂ emissions reductions achieved by CHP compared to SHP.¹⁶ The default values in the Calculator are based on the guidelines in this paper. However, users can also input selected CHP system characteristics and emissions factors for CHP fuel, displaced thermal fuel, and displaced grid electricity.

The EPA CHP Emissions Calculator is available at: <u>http://www.epa.gov/chp/basic/calculator.html</u>.

The following example shows how a user would operate the CHP Emissions Calculator to determine the fuel and CO₂ savings achieved by a CHP system. The example system is a 5 MW natural gas-fired combustion turbine and heat recovery boiler CHP system that provides heating for an industrial process at a facility in Pennsylvania. The CHP system is displacing thermal energy provided by an existing natural gas boiler and grid electricity in the RFC East subregion (the eGRID subregion that includes Pennsylvania).¹⁷

Calculator Input

The following figures show the calculator inputs that are needed to evaluate this system. Figure 4 shows the Calculator inputs related to the CHP system itself. For this example, the Calculator default values were used for the electric efficiency and the power-to-heat ratio of the CHP system.

¹⁶ The CHP Emissions Calculator also accounts for methane (CH4), nitrogen oxides (NOx), nitrous oxide (N2O), and sulfur dioxide (SO2).

¹⁷ Information about eGRID subregions is contained in Appendix B.

1. CHP: Type of System	Combustion Turbine			Submit		
2. CHP: Electricity Generating Capaci	ty (per unit)					
Norr	nal size range for this tech	5,000 kW	0 kW	Submit		
3. CHP: How Many Identical Units (i.e	., engines) Does This Sy	stem Have?				
		1		Submit		
4. CHP: How Many Hours per Year Do	es the CHP System Ope	rate?				
I will er	iter a value					
As a number of hours OR As a pe	per year rcentage	7,500		Submit		
5. CHP: Does the System Provide Hea	ting or Cooling or Both	?				
	Heating Only	•				
If Heating and Cooling: How many As a number of hours	of the 7,500 hours are in c per year	ooling mode?				
as a percentage of the 7,50	0 hours?	0%		Submit		
If Heating and Cooling: Does the S	ystem Provide Simultaneo No	ous Heating and Cooling?				
6. CHP: Fuel						
F	uel Type Natural Gas	Vie F	w Biomass and Coal uel Characteristics			
				Submit		
12. CHP: Electric Efficiency	er en efficiency in ene					
of th	er an emclency in <u>one</u> ne following blocks	Use default for this techr	nology			
Enter Generating Efficien	cy as %	29% (HHV)				
OR Enter Generating Efficiency as Btu/k ¹ OR Enter Generating Efficiency as Btu/k	Wh HHV Wh LHV	11,806 Btu/kWl 10,684 Btu/kW	h (HHV) h (LHV)	Submit		
13. CHP: Base Power to Heat Ratio						
The Power to Heat Ratio should reflect ONLY the thermal production of the generating unit (i.e., combustion turbine). Thermal Output of the duct burners (if equipped) should not be included.						
I will ente	r a Power to Heat ratio	Use default for this techn	Use the Calculator t	Thermal o calculate		
Power to He	eat Ratio	0.62	my Power to	Heat Ratio		
				Submit		

Figure 4: CHP Emissions Calculator – CHP System Characteristics

After entering the information about the CHP system to be evaluated, information is entered related to the displaced on-site thermal energy production (i.e., the thermal energy produced by the CHP system that replaces thermal energy formerly produced by an on-site boiler). Information about the thermal equipment and fuel provides the basis for calculating the displaced thermal fuel use and CO₂ emissions. Figure 5 shows the Calculator inputs related to the displaced thermal energy.

23. Displaced Thermal: Type of System:				
	Existing Gas	Boiler 🔽]	Submit
24. Displaced Thermal: If not a Natural Gas S	ystem: What	at is the Sulfur Conte	ent?	
l will enter a	value or	Commercial coal:	: 1% sulfur	
		Low sulfur oil: 0.05%	6 or 500 ppm	
Enter Sulfur Content as a percent OR ppm		0.00%	ppm	Submit
25. Displaced Thermal: What is the CO2 Emis Enter alternative value:	sion Rate f	or this Fuel? (defau 116.9	It completed for fuel in It Ib CO2/MMBtu	tem 23) Submit
26. Displaced Thermal: What is the Heat Con OR OR	tent of this	Fuel? (Enter a value 1,028 - -	n only <u>ONE</u> of the boxe Btu/cubic foot (HHV) Btu/gallon (HHV) Btu/lb (HHV)	s) Submit
27. Displaced Thermal: Efficiency (usually a t	ooiler) n efficiency	Use default for	this thermal technology	
Enter Generating Efficiency as %		80%		Submit

Figure 5: CHP Emissions Calculator – Displaced Thermal Energy

The equations for calculating fuel use and CO_2 emissions from displaced on-site thermal energy production are:

Fuel Use from Displaced On-site Thermal Energy Production (Equation 3):

 $F_T = CHP_T / \eta_T$ 257,964 MMBtu/yr = 206,371 MMBtu/yr / 80%

where:

 $\begin{array}{ll} F_T &= \mbox{Fuel Use from Displaced On-site Thermal Production (Btu)} \\ CHP_T &= CHP \mbox{ System Thermal Output (Btu)} \\ \eta_T &= \mbox{Thermal Equipment Efficiency (\%)} \end{array}$

CO₂ Emissions from Displaced On-site Thermal Production (Equation 4):

$$C_T = F_T * EF_F$$

30,155,992 lbs CO₂ = 257,964 MMBtu/yr * 116.9 lb CO₂/MMBtu

where:

 C_T = CO₂ emissions from displaced on-site thermal production (lbs CO₂) F_T = Thermal Fuel Savings (Btu) EF_F = Fuel Specific Emissions Factor (lbs CO₂/MMBtu)

The CHP Emissions Calculator inputs related to the displaced grid electricity are shown in Figure 6 below. eGRID emissions rates include: Total Output Emissions Rate, Fossil Fuel Output Emissions

Rate, and Non-Baseload Output Emissions Rate. The Partnership recommends using the Fossil Fuel Output Emissions Rate because it most accurately reflects the emissions of generation displaced by CHP(see eGRID information in Appendix B). The Partnership also recommends using the rate for the RFC East eGRID subregion which includes eastern Pennsylvania where this system is located. For transmission and distribution (T&D) losses, the Partnership recommends using the eGRID value for grid losses from the appropriate U.S. interconnect power grid. There are five U.S. interconnect power grids (Eastern, Western, ERCOT, Alaska, and Hawaii), and the appropriate grid for this example is the Eastern grid, with an average T&D losses of 5.82%.

29. Displaced Electricity: Generation Profile	
eGRID 2012 Average Fossil (2009 data) Link to EPA's eGRID (Emissions & Generation Resource Ir	ed Database) Modify one of the Three User-Defined Generating Submit
30. Displaced Electricity: Select U.S. Average or individu	te or NERC region/subregion for EGRID Data
24. Displaced Electricity, Coloct Electric Crid Degion for	mission and Distribution (TRD) Lasson
31. Displaced Electricity: Select Electric Grid Region for	mission and Distribution (1&D) Losses
Eastern Inter	5.82% Submit

Figure 6: CHP Emissions Calculator – Displaced Electricity

The total fuel use and CO₂ emissions of displaced grid electricity are calculated using the following equations:

Displaced Grid Electricity from CHP (Equation 5):

where:

39,817.4 MWh/year = 37,500 MWh/year / (1 - 5.82%)E_G = Displaced Grid Electricity from CHP (kWh) CHP_E = CHP System Electricity Output (kWh) L_{T&D} = Transmission and Distribution Losses (%)

 $E_G = CHP_E / (1-L_{T&D})$

Fuel Use from Displaced Grid Electricity (Equation 6):

 $F_{G} = E_{G} * HR_{G}$ 380,909 MMBtu/year = 39,817.4 MWh/year * 9,566 Btu/kWh / 1000

where:

 F_G = Fuel Use from Displaced Grid Electricity (Btu)

 E_{G} = Displaced Grid Electricity from CHP (kWh)

 HR_G = Grid Electricity Heat Rate (Btu/kWh)

CO₂ Emissions from Displaced Grid Electricity (Equation 7):

$$C_G = E_G * EF_G$$

67,211,771,200 lbs CO₂ = 39,817.4 MWh/year * 1,688 lb CO₂/kWh * 1000

where:

 C_G = CO₂ Emissions from Displaced Grid Electricity (lbs)

- E_G = Displaced Grid Electricity from CHP (kWh)
- EF_G = Grid Electricity Emissions Factor (CO₂ lb/kWh)

Calculator Results

Once the user has entered all of the information on the Inputs page of the Calculator and clicked the "Go to Results" button the Results page is displayed. Figure 7 illustrates the results for this example, which shows that the CHP system reduces overall fuel consumption by 196,018 MMBtu/year and CO_2 emissions by 22,794 tons/year.

Figure 7: CHP Emissions Calculator – Fuel and Emissions Savings Results

CHP Results	ØDE	SEPA COMBINED HE POWER PARTN	P AT AND ERSHIP	AUTON	All and a second second
The results generated by the CHP E it is not designed for use in develop	Emissions Calculator are ir ing emission inventories or	ntended for educ r preparing air pe	tional and outrea ermit applications	ach purposes only; s.	
Annual Emissions Analysis					
	CHP System	Displaced Electricity Production	Displaced Thermal Production	Emissions/Fuel Reduction	Percent Reduction
NO _x (tons/year)	20.35	27.80	12.90	20.35	50%
SO ₂ (tons/year)	0.13	167.11	0.08	167.05	100%
CO ₂ (tons/year)	25,885	33,601	15,078	22,794	47%
CH4 (tons/year)	0.488	0.965	0.284	0.761	61%
N ₂ O (tons/year)	0.049	0.538	0.028	0.517	91%
Total GHGs (CO2e tons/year)	25,910	33,788	15,093	22,970	47%
Carbon (metric tons/year)	6,400	8,308	3,728	5,636	47%
Fuel Consumption (MMBtu/year)	442,855	380,909	257,964	196,018	31%
Number of Cars Removed				3.991	
This CHP proje This	ct will reduce emissions is equal to 5,636 metric rer	of Greenhous tons of carbon This reduction noving the car of 3,991	e Gases (CO2e) equivalent (M h is equal to bon emissions cars	by 22,970 tons per ICE) per year	year

The equations for the relationship for total fuel savings and CO₂ savings are as follows:

Total Fuel Savings from CHP (Equation 1):

 $F_{S} = (F_{T} + F_{G}) - F_{CHP}$

196,018 MMBtu/year = (257,964 MMBtu/year + 380,909 MMBtu/year) - 442,855 MMBtu/year

where:

F_S = Total Fuel Savings

 F_T = Fuel Use from Displaced On-site Thermal Production

F_G = Fuel Use from Displaced Grid Electricity

 F_{CHP} = Fuel Used by the CHP System

Total CO₂ Savings from CHP (Equation 2):

$$C_{\rm S} = (C_{\rm T} + C_{\rm G}) - C_{\rm CHP}$$

22,794 lbs $CO_2 = (15,078$ lbs + 33,601 lbs) - 25,885 lbs

where:

 $\begin{array}{lll} C_{S} & = Total \ CO_{2} \ Emissions \ Savings \\ C_{T} & = CO_{2} \ Emissions \ from \ Displaced \ On-site \ Thermal \ Production \\ C_{G} & = CO_{2} \ Emissions \ from \ Displaced \ Grid \ Electricity \\ C_{CHP} & = CO_{2} \ Emissions \ from \ the \ CHP \ System \end{array}$

Figure 8 shows the outputs of the CHP system in more detail, and Figure 9 shows the emissions rates for the CHP system as well as those from the displaced thermal production and displaced electricity generation.

Figure 8: CHP Emissions Calculator, CHP Outputs

CHP Technology:	Combustion Tu	Irbine
Fuel:	Natural Gas	
Unit Capacity:	5,000	kW
Number of Units:	1	
Total CHP Capacity:	5,000	kW
Operation:	7,500	hours per year
Heat Rate:	11,809	Btu/kWh HHV
CHP Fuel Consumption:	442,855	MMBtu/year
Duct Burner Fuel Consumption:	-	MMBtu/year
Total Fuel Consumption:	442,855	MMBtu/year
Total CHP Generation:	37,500	MWh/year
Useful CHP Thermal Output:	206,371	MMBtu/year for thermal applications (non-cooling)
	-	MMBtu/year for electric applications (cooling and electric heating)
	206,371	MMBtu/year Total
Displaced On-Site Production for		Existing Gas Boiler
Thermal (non-cooling) Applications:	0.10	lb/MMBtu NOx
	0.00%	sulfur content
Displaced Electric Service (cooling and		
electric heating):		
	There is no dis	placed cooling service
Displaced Electricity Profile:	eGRID 2012 A	verage Fossil (2009 data)
Egrid State:	RFCE East	
Distribution Losses:	6%	
Displaced Electricity Production:	37,500	MWh/year CHP generation
	-	MWh/year Displaced Electric Demand (cooling)
	-	MWh/year Displaced Electric Demand (electric heating)
	2,317	MWh/year Transmission Losses
	39,817	MWh/year Total

Figure 9: CHP Emissions Calculator, Emissions Rates

Annual Analysis for CHP					
	CHP System:				
	Combustion			Total Emissions	
	Turbine			from CHP System	_
NO _x (tons/year)	20.35	-		20.35	
SO ₂ (tons/year)	0.13	-		0.13	
CO ₂ (tons/year)	25,885	-		25,885	
CH ₄ (tons/year)	0.488	-		0.488	
N ₂ O (tons/year)	0.049	-		0.049	
Total GHGs (CO ₂ e tons/year)	25,910	-		25,910	
Carbon (metric tons/year)	6,400	-		6,400	
Fuel Consumption (MMBtu/year)	442,855	-		442,855	
					-
Annual Analysis for Displaced Production	for Thermal (n	on-cooling) Ap	plications		-
				Total Displaced	
				Emissions from	
				Production	
NO., (tons/year)				12 90	-
SO ₂ (tons/year)				0.08	-
CO ₂ (tons/year)				15.078	-
CH ₄ (tons/year)				0 284	-
N ₂ O (tons/year)				0.028	-
Total GHGs (CO2e tons/year)				15.093	-
Carbon (metric tons/year)				3.728	
Fuel Consumption (MMBtu/year)				257,964	
	•				•
Annual Analysis for Displaced Electricity F	Production				
	Displaced				
	CHP	Displaced	Displaced		
	Electricity	Electricity for	Electricity for	Transmission	Total Displaced Emission
<u></u>	Generation	Cooling	Heating	Losses	from Electricity Generation
NO _x (tons/year)	26.18	-	-	1.62	27.80
SO ₂ (tons/year)	157.38	-	-	9.73	167.11
CO ₂ (tons/year)	31,645	-	-	1,955.56	33,601
CH ₄ (tons/year)	0.908	-	-	0.056	0.965
N ₂ O (tons/year)	0.506	-	-	0.031	0.538
Total GHGs (CO ₂ e tons/year)	31,821	-	-	1,966	33,788
Carbon (metric tons/year)	7,825	-	-	484	8,308
Fuel Consumption (MMBtu/year)	358,740	-	-	22,169	380,909



Appendix B: Displaced Grid Electricity Fuel Use and CO₂ Emissions

The displaced fuel use and CO_2 emissions associated with the operation of a CHP system can be determined by:

a. Calculating the fuel use and emissions from displaced separate heat and power (SHP) (i.e., grid-supplied electricity and on-site thermal generation such as a boiler)

- b. Calculating the fuel use and emissions from CHP
- c. Subtracting (b) from (a)

The challenge of calculating the fuel use and emissions associated with displaced grid electricity stems from the fact that grid electricity is generated by a large number of sources with different fuels and different heat rates. The sources that are reasonably expected to be displaced must therefore be determined in order to estimate the displaced fuel use and emissions.

Section 3.1.1 of this paper presents the Partnership's recommended methodology for calculating the fuel use and emissions from displaced thermal generation, and section 3.1.2 presents the recommended methodology for calculating the fuel use and emissions from displaced grid electricity. Section 3.2 presents the recommended methodology for calculating the fuel use and emissions from displaced grid electricity. Section 3.2

This appendix complements the methodology provided in section 3.1.2 by:

- Discussing use of EPA's Emissions & Generation Resource Integrated Database (eGRID) as a resource for the grid electricity heat rate (HR_G) and the grid electricity emissions factor (EF_G) needed to calculate the fuel and CO₂ emissions associated with displaced grid electricity from CHP.
- Explaining why, when calculating fuel and CO₂ emissions savings associated with CHP, the Partnership recommends using the following factors:
 - the eGRID all fossil emissions factor and heat rate for the eGRID subregion where the CHP system is located for baseload CHP (i.e., greater than 6,500 annual operating hours), and
 - the eGRID non-baseload emissions factor and heat rate for the eGRID subregion where the CHP system is located for CHP systems with relatively low annual capacity factors (i.e., less than 6,500 annual operating hours) and with most generation occurring during periods of high system demand.

B.1 EPA's Emissions & Generation Resource Integrated Database (eGRID)

Background

EPA's eGRID¹⁸ is a comprehensive and widely-used resource¹⁹ for information about electricitygenerating plants that provide power to the electric grid and report data to the U.S. government. eGRID provides data on:

¹⁸ EPA has generated and published detailed information on electricity generation and emissions since 1998. The most recent edition of eGRID, eGRID2012 version 1.0, was released in 2012 and contains data collected in 2009. More information is available at. <u>http://www.epa.gov/cleanenergy/energy-resources/egrid/index.html</u>

- Generation (MWh)
- Fuel use
- Plant heat rate
- Resource mix (e.g., coal, gas nuclear, wind, solar)
- Emissions associated with power generation in the United States

In order to enhance the usability of this data, eGRID separates and organizes it into useful levels of aggregation, as follows:

- Plant
- State
- Electric generating company (EGC)
- Power control area (PCA)
- eGRID subregion
- North American Electric Reliability Corporation (NERC) region
- U.S. total

Note:

- eGRID consists of historic sets of recent data; it does not include projections of the operating characteristics of generating units in the future.
- The generation data and related data categories provided by eGRID are based on generated electricity, not consumed (i.e., delivered) electricity and therefore do not include the impact of transmission and distribution (T&D) losses (see Section 3.1.2 and Equation 5 for more information on T&D losses).

Aggregation Level – eGRID subregion

EPA defines eGRID subregions based on NERC regions and PCAs. There are 26 eGRID subregions (see Figure B-1) in eGRID2012, and each consists of one PCA or a portion of a PCA. eGRID subregions generally represent sections of the grid that have similar resource mix and emissions characteristics.

¹⁹ According to the eGRID Technical Support Document, more than 40 tools, applications, and programs (public and private) rely on eGRID data.

Figure B-1: eGRID Subregion Map²⁰



Emissions and Heat Rate Data

eGRID presents the heat rate of each listed plant, and emissions data aggregated by fuel type and by generation source category (e.g., all fossil fuels). eGRID also presents emissions data for several pollutants—carbon dioxide (CO_2), nitrogen oxides (NO_X), sulfur dioxide (SO_2), methane (CH_4), nitrous oxide (N_2O) and mercury (Hg)—in the form of emissions rates on an output basis (Ib/MWh) and on a fuel input basis (Ib/MMBtu).

Notes on Terminology. For the sake of clarity and consistency, eGRID emission rates (lb/MWh) are referred to in this appendix as *emissions factors*. Also note that, because this document addresses how to calculate avoided CO_2 emissions, all subsequent references to eGRID emissions data in this appendix refer to CO_2 emissions only.

Three types of generation rates provided in eGRID are discussed in this appendix²¹:

Total Output

The Total Output rates are based on data for all power generation regardless of energy source (i.e., fossil, nuclear, hydro, and renewables) within a defined region or subregion. One CO_2 emissions factor (lb/MWh) and one heat rate (Btu/kWh) value are associated with the category for each NERC region and eGRID subregion.

²⁰ Many of the boundaries shown on this map are approximate because they are based on company location rather than on strict geographical boundaries.

²¹ In addition to the three eGRID generation categories listed here, eGRID also includes an "annual combustion output" category. This category is not discussed in this appendix since it was primarily developed to estimate NO_X and SO₂ emissions from combustion generating units that are dispatched to respond to marginal increases in electricity demand, and thus not applicable to CO2 calculations involving CHP.

Fossil Fuel Output

The Fossil Fuel Output rates are based on data for power generation from fossil fuel-fired plants within a defined region or subregion. One CO₂ emission factor (lb/MWh) and one heat rate (Btu/kWh) value are associated with the category for each NERC region and eGRID subregion. EPA characterizes this emissions factor as "a rough estimate to determine how much emissions could be avoided if energy efficiency and/or renewable energy displaces fossil fuel generation."²² The EPA CHP Partnership's CHP Emissions Calculator uses the emissions factor and heat rate from this category to determine emissions and fuel use from displaced grid electricity when evaluating CHP systems.²³

eGRID also provides emissions factors by specific fossil fuel type (i.e., for coal-, natural gas-, and oil-fired generating plants). These emissions factors are useful in assessing the different impacts of fossil fuels, but they are rarely used to evaluate the relationship between CHP and displaced grid electricity emissions.

Non-baseload Output

The Non-baseload Output rates are based on data for power generation from combustion generating units within a defined region or subregion that do not serve as baseload units. One CO₂ emissions factor (lb/MWh) and one heat rate (Btu/kWh) value are associated with the category for each NERC region and eGRID subregion. The term "baseload" refers to those plants that supply electricity to the grid even when demand for electricity is relatively low. Baseload plants are usually brought online to provide electricity to the grid regardless of the level of demand, and they generally operate continuously except when undergoing routine or unscheduled maintenance. EPA developed the non-baseload output emissions factors to estimate emissions reductions from energy efficiency projects and certain types of clean energy projects based on the emissions from generating units that are dispatched to respond to marginal increases in electricity demand.²⁴ eGRID calculates the non-baseload factors by weighting each plant's emissions and generation according to its capacity factor. The generation and emissions from plants that operate most of the time, (that is, baseloaded plants with annual capacity factors greater than 0.8) are excluded. All the generation and emissions from fuel-based plants that operate infrequently during the year (for example, peaking units with capacity factors less than 0.2) are included. A portion of the emissions and generation from the remaining fuel-based plants (i.e., those with capacity factors between 0.2 and 0.8) are included, with higher portions used for plants with lower capacity factors and lower portions used for plants with higher capacity factors.

Table B-1 provides the all generation, all fossil, and non-baseload emissions factors from eGRID.

http://www.epa.gov/cleanenergy/documents/egridzips/eGRID2012 year09 TechnicalSupportDocument.pdf

²² "EPA eGRID Technical Support Document. April 2012.

 ²³ The CHP Emissions Calculator is available at: <u>http://www.epa.gov/chp/basic/calculator.html</u>
 ²⁴ Rothschild, S. and Diem, A., "Guidance on the Use of eGRID Output Emissions Rates", http://www.epa.gov/ttn/chief/conference/ei18/session5/rothschild.pdf