



HAWAII STATE ENERGY OFFICE STATE OF HAWAII

235 South Beretania Street, 5th Floor, Honolulu, Hawaii 96813
Mailing Address: P.O. Box 2359, Honolulu, Hawaii 96804

Telephone:
Web:

JOSH GREEN, M.D.
GOVERNOR

SYLVIA LUKE
LT. GOVERNOR

MARK B. GLICK
CHIEF ENERGY OFFICER

(808) 451-6648
energy.hawaii.gov

Testimony of **MARK B. GLICK, Chief Energy Officer**

before the
SENATE COMMITTEE ON ENERGY , ECONOMIC DEVELOPMENT, AND TOURISM

Thursday, March 14, 2024
1:01 PM
State Capitol, Conference Room 229 and Videoconference

In Support of
HB 2103, HD2

RELATING TO LONG DURATION CLEAN ENERGY STORAGE.

Chair DeCoite, Vice Chair Wakai and members of the Committee, I am writing in support of HB 2103, HD2, which relates to long duration clean energy storage.

Longer duration storage technologies will be increasingly important to Hawai'i's energy transition as more renewables are deployed on the grid. At high rates of renewable penetration, such storage enables renewable sources generated during the daytime, such as solar generated power, to be used throughout the night. A long duration clean energy storage investment capital special fund would provide the Hawai'i State Energy Office (HSEO) with seed and venture capital for investments in private sector and federal projects for long duration storage research, development, testing, and implementation.

Long-duration storage, including hydrogen (H₂) and pumped hydroelectric storage, can make renewable energy available in times of need. It further has the potential to act as firm renewable, subject to the storage capacity. Kauai Island Utility Cooperation (KIUC) issued a Power Purchase Agreement (PPA) at \$0.08/kWh PPA for a pumped hydroelectric storage project combining 35MW solar and battery, and 25MW pumped hydro. KIUC estimates project will save over \$150 million compared to fossil fuels for term of PPA.

O'ahu has the potential for pumped hydro at Lake Wilson. Previous estimates show 40MW capacity from Wahiawā, Nu'uānu, and Maunawili reservoirs (USDOE and DBEDT 1981).

The measure as written provides sufficient flexibility to pursue electrochemical, mechanical, thermal, chemical carriers, or any combination that has the potential to meet the necessary duration and cost targets for grid flexibility. The changes also preserve the crucial role of hydrogen pursuant to the original intent of the renewable hydrogen program but broadens it appropriately to include all long duration storage options.

Thank you for the opportunity to testify.